

**MONTGOMERY COUNTY HISTORIC PRESERVATION COMMISSION**  
**STAFF REPORT**

<b>Address:</b>	7013 Poplar Ave., Takoma Park	<b>Meeting Date:</b>	3/11/2026
<b>Resource:</b>	Outstanding Resource <b>Takoma Park Historic District</b>	<b>Report Date:</b>	3/4/2026
<b>Applicant:</b>	Jeremiah Frueauf Tina Crouse (agent)	<b>Public Notice:</b>	2/25/2026
<b>Review:</b>	HAWP	<b>Tax Credit:</b>	No
<b>Case Number:</b>	1145456	<b>Staff:</b>	Devon Murtha
<b>Proposal:</b>	Solar panel installation		


---

**RECOMMENDATION**

Staff recommends that the Historic Preservation Commission **approve** the HAWP application

**PROPERTY DESCRIPTION**

**SIGNIFICANCE:** Outstanding Resource to the Takoma Park Historic District  
**STYLE:** Queen Anne  
**DATE:** c. 1885-1900



*Figure 1: 7013 Poplar Avenue is located within the Takoma Park Historic District, annotated with a yellow star.*


## PROPOSAL

The subject property is located on a large lot along Poplar Avenue and contains a two-and-a-half-story house executed in the Queen Anne Style. It is an Outstanding Resource within the Takoma Park Historic District. The house features a side-gabled roof and a one-story front porch. A large two-story addition was added to the rear of the property in 1987.<sup>1</sup> There is also a small garage on the rear of the property.



*Figure 2: View of subject property from right-of-way along Poplar Avenue.*

The applicant proposes to install fourteen (14) solar panels in three (3) arrays on the main roof of the subject property. The Q-TRON BLK M-G2+ series panels will be mounted to the asphalt shingle roof with SnapRack mounts.



*Figure 3: Solar panel layout (left) and site plan (right).*

<sup>1</sup> See HAWP approval for addition here:

[https://mcatlas.org/tiles/06\\_HistoricPreservation\\_PhotoArchives/Padlock/HAR60640006/Box044/37-3\\_Takoma%20Park%20Historic%20District\\_7013%20Poplar%20Avenue\\_10-02-1987.pdf](https://mcatlas.org/tiles/06_HistoricPreservation_PhotoArchives/Padlock/HAR60640006/Box044/37-3_Takoma%20Park%20Historic%20District_7013%20Poplar%20Avenue_10-02-1987.pdf).




Figure 4: Specifications for the solar panels.




Figure 5: Installation details for the SnapRack mounts.

### APPLICABLE GUIDELINES

The Historic Preservation Office and Historic Preservation Commission (HPC) consult several documents when reviewing alterations and new construction within the Takoma Park Historic District. These documents include the historic preservation review guidelines in the approved and adopted amendment for

the *Takoma Park Historic District (Guidelines)*, *Montgomery County Code Chapter 24A (Chapter 24A)*, the *Secretary of the Interior's Standards for Rehabilitation (Standards)*, and the HPC's *Policy No. 20-01: Addressing Emergency Climate Mobilization Through The Installation of Roof-Mounted Solar Panels*, The pertinent information in these four documents is outlined below.

### ***Takoma Park Historic District Guidelines***

There are two broad planning and design concepts which apply to all categories. These are:

- The design review emphasis will be restricted to changes that are all visible from the public right-of-way, irrespective of landscaping or vegetation (it is expected that the majority of new additions will be reviewed for their impact on the overall district), and
- The importance of assuring that additions and other changes to existing structures act to reinforce and continue existing streetscape, landscape, and building patterns rather than to impair the character of the historic district.

Outstanding Resources – Residential: These resources have the highest level of architectural and/or historical significance. While they will receive the most detailed level of design review, it is permissible to make sympathetic alterations, changes and additions to Outstanding Resources.

As a set of guiding principles for design review of Outstanding Resources, the Historic Preservation Commission will utilize the Secretary of the Interior's "Standards for Rehabilitation".

Specifically, some of the factors to be considered in reviewing HAWPs on Outstanding Resources:

Plans for all alterations should be compatible with the resource's original design; additions, specifically, should be sympathetic to existing architectural character, including massing, height, setback, and materials

Preservation of original and distinctive architectural features, such as porches, dormers, decorative details, shutters, etc..is encouraged

All changes and additions should respect existing environmental settings, landscaping, and patterns of open space

### ***Montgomery County Code, Chapter 24A-8***

The following guidance which pertains to this project are as follows:

- (b) The commission shall instruct the director to issue a permit, or issue a permit subject to such conditions as are found to be necessary to ensure conformity with the purposes and requirements of this chapter, if it finds that:
  - (1) The proposal will not substantially alter the exterior features of an historic site or historic resource within an historic district; or
  - (2) The proposal is compatible in character and nature with the historical, archeological, architectural or cultural features of the historic site or the historic district in which an historic resource is located and would not be detrimental thereto or to the achievement of the purposes of this chapter;

- (4) The proposal is necessary in order that unsafe conditions or health hazards be remedied
- (d) In the case of an application for work on an historic resource located within an historic district, the commission shall be lenient in its judgment of plans for structures of little historical or design significance or for plans involving new construction, unless such plans would seriously impair the historic or architectural value of surrounding historic resources or would impair the character of the historic district. (Ord. No. 9-4, § 1; Ord. No. 11-59.)

***Secretary of the Interior’s Standards for Rehabilitation***

The Secretary of the Interior defines rehabilitation as “the act or process of making possible a compatible use for a property through repair, alterations, and additions while preserving those portions or features, which convey its historical, cultural, or architectural values.” The applicable *Standards* are as follows:

2. The historic character of a property will be retained and preserved. The removal of distinctive materials or alteration of features, spaces and spatial relationships that characterize a property will be avoided.
9. New additions, exterior alterations, or related new construction shall not destroy historic materials that characterize the property. The new work shall be differentiated from the old and shall be compatible with the massing, size, scale, and architectural features to protect the historic integrity of the property and its environment.
10. New additions and adjacent or related new construction shall be undertaken in such a manner that if removed in the future, the essential form and integrity of the historic property and its environment would be unimpaired.

***Historic Preservation Commission Policy No. 20-01: Addressing Emergency Climate Mobilization Through The Installation of Roof-Mounted Solar Panels***

Now, THEREFORE:

WHEREAS, Historic Area Work Permit decisions are guided by the criteria in Section 24A, The Secretary of the Interior’s Standards for Rehabilitation, and pertinent guidance from applicable master plan amendments and/or site or district-specific studies;

WHEREAS, The Secretary of the Interior’s Standards for Rehabilitation as interpreted by the National Park Service limit the placement of rooftop solar panels under Standards 2, 9, and 10 to less conspicuous locations;

WHEREAS, the County Council has established a Climate Emergency;

WHEREAS, the Historic Preservation is a body established by the County Executive and County Council;

WHEREAS, Section 24-8(b)(6) states, “In balancing the interest of the public in preserving the historic site or historic resource located within an historic district, with the interests of the public from the use and benefit of the alternative proposal, the general public welfare is better served by granting the permit;”

WHEREAS, the widespread use of solar panels, both for hot water and for electricity production, will reduce greenhouse gases in the county, in accordance with the aims of the Emergency Climate Mobilization resolution (Resolution No.: 18-974), it shall be the policy of the Historic Preservation Commission that:


1. The preferred locations for solar panel installation(s) on a designated historic site or an historic resource located within an historic district is a) on the rear of the property, b) on non-historic building additions, c) on accessory structures, or d) in ground-mounted arrays;
2. If it is not feasible to install solar panels in one of the identified preferred locations due to resource orientation or other site limitations; and,
3. The roof is determined to be neither architecturally significant, nor a character-defining feature of the resource, nor is it a slate or tile roof, that unless it can be demonstrated that the solar array will be installed without damaging the historic character of the resource or historic fabric; then
4. The public welfare is better served by approving a Historic Area Work Permit for solar panels on all visible side or front roof slopes under Section 24A-8(b)(6).
5. A Historic Area Work Permit (HAWP) is required for all work referenced in this policy.

### **STAFF DISCUSSION**

Staff supports the proposal and recommends approval.


Staff evaluated the proposed placement of the solar panels on the subject property against the guidance provided by *Historic Preservation Commission Policy No. 20-01*. In determining the most appropriate placement of solar panels, the policy outlines several preferred locations, including (in order of preference), in ground-mounted arrays, on accessory structures, on non-historic building additions, and on the rear of the property. Installation of solar panels on the primary preferred location (ground-mounted array) is not possible for this project due to the lot size and canopy cover. Installation on the secondary preferred location (accessory structure) is also not feasible for this project, as there is limited sunlight to that area due to the extensive tree canopy.

One of the arrays will be installed on the tertiary preferred location (the non-historic building addition; *Figure 6*), consistent with *Policy No. 20-01*.



*Figure 6: Solar panels on non-historic addition indicated with red box (left) and arrow (right).*

Staff acknowledge that two of the arrays will be installed on the historic main roof, which is a non-preferred location, but only one array will be visible from the right-of-way along Poplar Avenue. Staff finds that this location is still acceptable, as the applicant submitted sufficient justification demonstrating that there are no other feasible locations for the panels. The north-facing roof slopes are not oriented to receive enough sunlight for optimal solar panel operation. The south-facing rear porch is not an option due to the presence of egress windows, which require additional setbacks per DPS requirements. The subject property had an estimated annual usage of roughly 17,420 kWh in 2025, and the proposed system will only generate a fraction of that at 3,689 kWh in annual production. Staff finds that the removal of any panels from this system, or movement to other roof planes, would lessen the production even further, to the detriment of the project feasibility.



*Figure 7: Solar panels on main roof indicated with red box (left) and arrow (right).*

Per the *Guidelines*, Staff finds that the installation of these panels will not impact the existing pattern of the streetscape. Photovoltaic systems are already an established element of the district and the HPC has approved the installation of solar panels in locations visible from the right-of-way, including on the main roof (*Figure 8*). Staff does not find the house's roof shape or asphalt shingles to be architecturally significant and that the solar installation will not damage the house's historic character.



*Figure 8: Solar panels installed on properties that are visible from the right-of-way along the 7000 Block of Poplar Avenue include 7004 Poplar (annotated with a red box, left), 7101 Poplar (annotated with a red box, right), and 7112 Poplar (not pictured). The subject property is annotated with a blue box.*

The application indicates that a tree in the front yard is to be removed by the homeowner. Staff notes that tree removals require approval from the HPC. The applicant must return to the HPC for permission to remove the tree, or submit more information to Staff regarding the tree removal if a tree removal waiver is issued.




Figure 9: Heat map for the subject property.

After full and fair consideration of the applicant’s submission, staff finds the proposal, as modified by the conditions, consistent with the Criteria for Issuance in Chapter 24A-8(b)(1), (2), and (d), having found the proposal is consistent with the *Secretary of the Interior’s Standards for Rehabilitation #2, 9, and 10*, and *Takoma Park Historic District Guidelines*, and the *HPC’s Policy No. 20-01* as outlined above.

**STAFF RECOMMENDATION**

Staff recommends the Historic Preservation Commission **approve** the HAWP; under the Criteria for Issuance in Chapter 24A-8(b)(1), (2) and (d), having found that the proposal will not substantially alter the exterior features of the historic resource and is compatible in character with the district and the purposes of Chapter 24A;

*The Takoma Park Historic District Guidelines;*

*the Secretary of the Interior’s Standards for Rehabilitation #2 and #10;*

*and with the Historic Preservation Commission Policy No. 20-01: Addressing Emergency Climate Mobilization Through The Installation of Roof-Mounted Solar Panels;*

and with the general condition that the applicant shall present an electronic set of drawings, if applicable, to Historic Preservation Commission (HPC) staff for review and stamping prior to submission for the Montgomery County Department of Permitting Services (DPS) building permits;

and with the general condition that final project design details, not specifically delineated by the Commission, shall be approved by HPC staff or brought back to the Commission as a revised HAWP

application at staff's discretion;

and with the general condition that the applicant shall notify the Historic Preservation Staff if they propose to make **any alterations** to the approved plans. Once the work is completed the applicant will contact the staff person assigned to this application at 301-563-3400 or [devon.murtha@montgomeryplanning.org](mailto:devon.murtha@montgomeryplanning.org) to schedule a follow-up site visit.

**Description of Property:** Please describe the building and surrounding environment. Include information on significant structures, landscape features, or other significant features of the property:

**Description of Work Proposed:** Please give an overview of the work to be undertaken:

Work Item 1: _____	
Description of Current Condition:	Proposed Work:

Work Item 2: _____	
Description of Current Condition:	Proposed Work:

Work Item 3: _____	
Description of Current Condition:	Proposed Work:

**HISTORIC AREA WORK PERMIT  
CHECKLIST OF  
APPLICATION REQUIREMENTS**

	Required Attachments						
Proposed Work	I. Written Description	2. Site Plan	3. Plans/ Elevations	4. Material Specifications	5. Photographs	6. Tree Survey	7. Property Owner Addresses
New Construction	*	*	*	*	*	*	*
Additions/ Alterations	*	*	*	*	*	*	*
Demolition	*	*	*		*		*
Deck/Porch	*	*	*	*	*	*	*
Fence/Wall	*	*	*	*	*	*	*
Driveway/ Parking Area	*	*		*	*	*	*
Grading/Excavation/ Landscaping	*	*		*	*	*	*
Tree Removal	*	*		*	*	*	*
Siding/ Roof Changes	*	*	*	*	*		*
Window/ Door Changes	*	*	*	*	*		*
Masonry Repair/ Repoint	*	*	*	*	*		*
Signs	*	*	*	*	*		*



Front of Home



Back of Home



Right side of Home



Left side of Home




Before Install



After Installation



# DAVID C. HERNANDEZ, PE

513-418-8812 

4912 Prospect Ave., Blue Ash OH 45242 

davehernandezpe@gmail.com 

DATE: December 19, 2025

RE: 7013 Poplar Ave, Takoma Park, MD 20912, USA

To Whom It May Concern,

As per your request, Exactus Energy has conducted a site assessment of the building at the above address.

PV solar panels are proposed to be installed on roof areas as shown in the submitted plans. The panels are attached to the roof decking with a rail-less mounting system. The PV system (PV modules, racking, mounting hardware, etc.) shall be installed according to the manufacturer's approved installation specifications. The Engineer of Record and Exactus Energy claim no responsibility for misuse or improper installation.

It was found that the roof systems satisfactorily meet the applicable standards included in the IBC 2021, IRC 2021, and ASCE 7-16 as well as the design criteria shown below:

Design Criteria:

Risk Category	= II
Exposure Category	= B
Wind speed	= 115 mph
Ground snow load	= 30 psf
Roof dead load	= 12 psf
Solar system dead load	= 3 psf

Overall, the roof system integrity is adequate to support the PV alteration with no modifications or reinforcements required.

This letter was completed in accordance to recognized design standards, professional engineering experience, and judgement. Prior to installation, the on-site contractor must notify Exactus Energy if there are any discrepancies, or damages to the members, that was not addressed in the plan set.

If you have any further questions, please do not hesitate to contact me.

Acknowledged by:


David C. Hernandez, PE Digitally signed by David C. Hernandez, PE  
Date: 2025.12.19 17:37:28 -05:00



PROFESSIONAL CERTIFICATION. I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND, LICENSE NO. 49993, EXP. 10/06/2026.



# DAVID C. HERNANDEZ, PE

513-418-8812 

4912 Prospect Ave., Blue Ash OH 45242 

davehernandezpe@gmail.com 

## SEISMIC CHECK

Breakdown of Loads		
Asphalt Shingles:	7	psf
Insulation:	1.5	psf
Plywood Sheathing:	1.5	psf
Rafters:	1	psf
Misc:	1	psf
Live load:	20	psf

Existing Roof Seismic Weight			
Element	Unit Weight (psf)	Area (Sq.ft)	Weight (lbs)
Roof DL	12	1893.00	22716
Exterior Walls	8	2032.00	16256
Interior Walls	6	2032.00	12192
Existing Seismic Weight @Roof Level, $W_e =$			51164

New PV System Seismic Weight			
Element	Unit Weight (psf)	Area (Sq.ft)	Weight (lbs)
Pv System	3	294.28	882.84
Seismic Weight of New PV System, $W_{pv} =$			882.84

% Increase in Lateral (Seismic) Weight @Roof Level Due to PV System Addition, %-increase = $W_{pv} / W_e$	1.73%	< 10% - Pass
---	-------	--------------



COMPANY

PROJECT

Dec. 19, 2025 09:13


7013 Poplar Ave - Roof 1.wwbu

**Design Check Calculation Sheet**  
WoodWorks Sizer 13.3

**Loads:**

Load	Type	Distribution	Pat-tern	Location [ft]		Magnitude		Unit
				Start	End	Start	End	
DL-WOOD	Dead	Full Area	No			12.00	(16.0")	psf
DL-PV	Dead	Partial Area	No	0.50	9.00	3.00	(16.0")	psf
SL1	Snow	Partial Area	No	0.00	0.50	23.10	(16.0")	psf
SL-PV	Snow	Partial Area	No	0.50	9.00	13.48	(16.0")	psf
SL2	Snow	Partial Area	No	9.00	11.44	23.10	(16.0")	psf
LL1	Roof constr.	Partial Area	No	0.00	0.50	20.00	(16.0")	psf
LL2	Roof constr.	Partial Area	No	9.00	11.44	20.00	(16.0")	psf

**Reactions (lbs), Bearing Capacities (lbs) and Bearing Lengths (in) :**



Unfactored:			
Dead		149	117
Snow		123	121
Roof Live		21	57
Factored:			
Combined		272	238
Bearing:			
F'theta		550	550
Capacity			
Joist		721	412
Support		586	586
Des ratio			
Joist		0.38	0.58
Support		0.46	0.41
Load comb		#3	#3
Length		0.50*	0.50*
Min req'd		0.50*	0.50*
Cb		1.75	1.00
Cb min		1.75	1.00
Cb support		1.25	1.25
Fcp sup		625	625

\*Minimum bearing length setting used: 1/2" for end supports and 1/2" for interior supports

**Lumber-soft, S-P-F, No.1/No.2, 2x10 (1-1/2"x9-1/4")**

Supports: All - Timber-soft Beam, D.Fir-L No.2

Roof joist spaced at 16.0" c/c; Total length: 14.57'; Clear span(horz): 0.979', 10.378'; Volume = 1.4 cu.ft.; Pitch: 8.5/12  
Lateral support: top = continuous, bottom = at supports; Repetitive factor: applied where permitted (refer to online help);

**This section PASSES the design code check.**

**Analysis vs. Allowable Stress and Deflection using NDS 2018 :**

Criterion	Analysis Value	Design Value	Unit	Analysis/Design
Shear	fv = 18	Fv' = 155	psi	fv/Fv' = 0.12
Bending(+)	fb = 323	Fb' = 1273	psi	fb/Fb' = 0.25
Bending(-)	fb = 14	Fb' = 576	psi	fb/Fb' = 0.02
Deflection:				
Interior Live	0.05 = < L/999	0.64 = L/240	in	0.09
Total	0.16 = L/984	0.85 = L/180	in	0.18
Cantil. Live	-0.02 = L/913	0.12 = L/120	in	0.13
Total	-0.05 = L/314	0.16 = L/90	in	0.29

**Additional Data:**

FACTORS:	F/E(psi)	CD	CM	Ct	CL	CF	Cfu	Cr	Cfrt	Ci	LC#
Fv'	135	1.15	1.00	1.00	-	-	-	-	1.00	1.00	3
Fb'+	875	1.15	1.00	1.00	1.000	1.100	-	1.15	1.00	1.00	3
Fb'-	875	1.15	1.00	1.00	0.452	1.100	-	1.15	1.00	1.00	3
Fcp'	425	-	1.00	1.00	-	-	-	-	1.00	1.00	-
E'	1.4 million	1.00	1.00	1.00	-	-	-	-	1.00	1.00	3
Emin'	0.51 million	1.00	1.00	1.00	-	-	-	-	1.00	1.00	3

**CRITICAL LOAD COMBINATIONS:**

Shear : LC #3 = D + S

Bending(+): LC #3 = D + S

Bending(-): LC #3 = D + S

Deflection: LC #3 = D + S (live)

LC #3 = D + S (total)

Bearing : Support 1 - LC #3 = D + S

Support 2 - LC #3 = D + S

Load Types: D=dead S=snow Lr=roof live

All LC's are listed in the Analysis output

Load combinations: ASD Basic from ASCE 7-16 2.4

**CALCULATIONS:**

V max = 193, V design = 166 (NDS 3.4.3.1(a)) lbs

M(+) = 576 lbs-ft; M(-) = 24 lbs-ft

EI = 138.50e06 lb-in<sup>2</sup>

"Live" deflection is due to all non-dead loads (live, wind, snow...)

Total deflection = 1.50 permanent + "live"

Bearing: Allowable bearing at an angle F'theta calculated for each support as per NDS 3.10.3

Lateral stability(-): Lu = 12.75' Le = 20.69' RB = 32.0; Lu based on full span

**Design Notes:**

1. Analysis and design are in accordance with the ICC International Building Code (IBC 2021) and the National Design Specification (NDS 2018), using Allowable Stress Design (ASD). Design values are from the NDS Supplement.
2. Please verify that the default deflection limits are appropriate for your application.
3. Continuous or Cantilevered Beams: NDS Clause 4.2.5.5 requires that normal grading provisions be extended to the middle 2/3 of 2 span beams and to the full length of cantilevers and other spans.
4. Sawn lumber bending members shall be laterally supported according to the provisions of NDS Clause 4.4.1.
5. SLOPED BEAMS: level bearing is required for all sloped beams.
6. The critical deflection value has been determined using maximum back-span deflection. Cantilever deflections do not govern design.



**COMPANY**

Dec. 19, 2025 09:12

**PROJECT**


7013 Poplar Ave - Roof 2 & Roof 3.wwbu

**Design Check Calculation Sheet**  
WoodWorks Sizer 13.3

**Loads:**

Load	Type	Distribution	Pat-tern	Location [ft]		Magnitude		Unit
				Start	End	Start	End	
DL-WOOD	Dead	Full Area	No			12.00	(16.0")	psf
DL-PV	Dead	Partial Area	No	0.50	8.00	3.00	(16.0")	psf
SL1	Snow	Partial Area	No	0.00	0.50	19.19	(16.0")	psf
SL-PV	Snow	Partial Area	No	0.50	8.00	10.40	(16.0")	psf
SL2	Snow	Partial Area	No	8.00	8.68	19.19	(16.0")	psf
LL1	Roof constr.	Partial Area	No	0.00	0.50	20.00	(16.0")	psf
LL2	Roof constr.	Partial Area	No	8.00	8.68	20.00	(16.0")	psf

**Reactions (lbs), Bearing Capacities (lbs) and Bearing Lengths (in) :**



Unfactored:			
Dead		129	100
Snow		74	60
Roof Live		15	17
Factored:			
Combined		203	160
Bearing:			
F'theta		616	616
Capacity			
Joist		808	462
Support		586	586
Des ratio			
Joist		0.25	0.35
Support		0.35	0.27
Load comb		#3	#3
Length		0.50*	0.50*
Min req'd		0.50*	0.50*
Cb		1.75	1.00
Cb min		1.75	1.00
Cb support		1.25	1.25
Fcp sup		625	625

\*Minimum bearing length setting used: 1/2" for end supports and 1/2" for interior supports

**Lumber-soft, S-P-F, No.1/No.2, 2x10 (1-1/2"x9-1/4")**

Supports: All - Timber-soft Beam, D.Fir-L No.2

Roof joist spaced at 16.0" c/c; Total length: 12.48'; Clear span(horz): 0.979', 7.618'; Volume = 1.2 cu.ft.; Pitch: 11/12  
Lateral support: top = continuous, bottom = at supports; Repetitive factor: applied where permitted (refer to online help);**This section PASSES the design code check.****Analysis vs. Allowable Stress and Deflection using NDS 2018 :**

Criterion	Analysis Value	Design Value	Unit	Analysis/Design
Shear	fv = 11	Fv' = 155	psi	fv/Fv' = 0.07
Bending(+)	fb = 163	Fb' = 1273	psi	fb/Fb' = 0.13
Bending(-)	fb = 13	Fb' = 679	psi	fb/Fb' = 0.02
Deflection:				
Interior Live	0.01 = < L/999	0.52 = L/240	in	0.03
Total	0.05 = < L/999	0.69 = L/180	in	0.08
Cantil. Live	-0.01 = < L/999	0.14 = L/120	in	0.04
Total	-0.02 = L/752	0.18 = L/90	in	0.12

**Additional Data:**

FACTORS:	F/E(psi)	CD	CM	Ct	CL	CF	Cfu	Cr	Cfrt	Ci	LC#
Fv'	135	1.15	1.00	1.00	-	-	-	-	1.00	1.00	3
Fb'+	875	1.15	1.00	1.00	1.000	1.100	-	1.15	1.00	1.00	3
Fb'-	875	1.15	1.00	1.00	0.534	1.100	-	1.15	1.00	1.00	3
Fcp'	425	-	1.00	1.00	-	-	-	-	1.00	1.00	-
E'	1.4 million	1.00	1.00	1.00	-	-	-	-	1.00	1.00	3
Emin'	0.51 million	1.00	1.00	1.00	-	-	-	-	1.00	1.00	3

**CRITICAL LOAD COMBINATIONS:**

Shear : LC #3 = D + S  
 Bending(+): LC #3 = D + S  
 Bending(-): LC #3 = D + S  
 Deflection: LC #3 = D + S (live)  
 LC #3 = D + S (total)

Bearing : Support 1 - LC #3 = D + S  
 Support 2 - LC #3 = D + S

Load Types: D=dead S=snow Lr=roof live

All LC's are listed in the Analysis output

Load combinations: ASD Basic from ASCE 7-16 2.4

**CALCULATIONS:**

V max = 118, V design = 100 (NDS 3.4.3.1(a)) lbs

M(+) = 290 lbs-ft; M(-) = 23 lbs-ft

EI = 138.50e06 lb-in<sup>2</sup>

"Live" deflection is due to all non-dead loads (live, wind, snow...)

Total deflection = 1.50 permanent + "live"

Bearing: Allowable bearing at an angle F'theta calculated for each support as per NDS 3.10.3

Lateral stability(-): Lu = 10.38' Le = 17.25' RB = 29.2; Lu based on full span

**Design Notes:**

1. Analysis and design are in accordance with the ICC International Building Code (IBC 2021) and the National Design Specification (NDS 2018), using Allowable Stress Design (ASD). Design values are from the NDS Supplement.
2. Please verify that the default deflection limits are appropriate for your application.
3. Continuous or Cantilevered Beams: NDS Clause 4.2.5.5 requires that normal grading provisions be extended to the middle 2/3 of 2 span beams and to the full length of cantilevers and other spans.
4. Sawn lumber bending members shall be laterally supported according to the provisions of NDS Clause 4.4.1.
5. SLOPED BEAMS: level bearing is required for all sloped beams.
6. The critical deflection value has been determined using maximum back-span deflection. Cantilever deflections do not govern design.

**ASCE 7 - 16 WIND CALCULATION FOR: Roof 1**  
**Project Address: 7013 Poplar Ave, Takoma Park, MD 20912, USA**

**DESIGN CRITERIA**

Ultimate Wind Speed: 115 mph	Array Edge Factor, $\gamma_E$ : 1
Exposure Category: B	Solar Array Dead Load: 3 psf
a: 3 ft	Mean Roof Height: 16 ft
Velocity Pressure Exposure Coefficient, $K_z$ : 0.59	Roof Pitch: 35°
Topographic Factor, $K_{zt}$ : 1	Roof Type: Gable
Wind Directionality Factor, $K_d$ : 0.85	Module Name, Dimensions, Area: LONGI LR5-54HPB-405M, 44.6in X 67.8in, 3023.88 sqin
Ground Elevation Factor, $K_e$ : 1	
Solar Array Pressure Equalization Factor, $\gamma_a$ : 0.61	

**CALCULATION**

Velocity Pressure Due to Wind:	$q_h = 0.00256(K_z)(K_{zt})(K_d)(I)(V^2)$	(Ch 26. Eq 26.10 – 1)
Actual Uplift Pressure:	$p = 0.6D + 0.6W$	(Ch 2.4.1 LC #7/a)
Wind Uplift Pressure:	$p = qh (GC_p)(\gamma_E)(\gamma_a)$	(Ch 29. Eq 29.4 – 7)

**Landscape / Portrait Panels**

Roof Zone	1	2e	2n	2r	3e	3r
Mount Spacing	67.8"	67.8"	67.8"	67.8"	67.8"	67.8"
External Pressure Coefficient (GC <sub>p</sub> )	-1.78	-1.78	-1.98	-1.78	-2.47	-1.98
Actual Uplift Pressure (p)	-16 psf	-16 psf	-16 psf	-16 psf	-16 psf	-16 psf
Tributary Area (AT)	10.5 sqft	10.5 sqft	10.5 sqft	10.5 sqft	10.5 sqft	10.5 sqft
Uplift Force (P)	-167.99 lbs	-167.99 lbs	-167.99 lbs	-167.99 lbs	-167.99 lbs	-167.99 lbs

**Uplift Capacity**

Attachment Type = 4 pcs of #14 Wood Screw TopSpeed Mount Assembly	Hardware Pullout Capacity = 258 lbs
Embedment Depth = 0.5 in	Safety Factor = 1.5
	Duration Factor = 1.6

Maximum Uplift Force = 167.993 lbs

Allowable Pullout Capacity = 258 lbs

Allowable Pullout Capacity = 258 lbs > Uplift Force per Bolt = 167.99 lbs, Therefore OK.

**ASCE 7 - 16 WIND CALCULATION FOR: Roof 2 & Roof 3**  
**Project Address: 7013 Poplar Ave, Takoma Park, MD 20912, USA**

**DESIGN CRITERIA**

Ultimate Wind Speed: 115 mph	Array Edge Factor, $\gamma_E$ : 1
Exposure Category: B	Solar Array Dead Load: 3 psf
a: 3 ft	Mean Roof Height: 16 ft
Velocity Pressure Exposure Coefficient, $K_z$ : 0.59	Roof Pitch: 43°
Topographic Factor, $K_{zt}$ : 1	Roof Type: Gable
Wind Directionality Factor, $K_d$ : 0.85	Module Name, Dimensions, Area: LONGI LR5-54HPB-405M, 44.6in X 67.8in, 3023.88 sqin
Ground Elevation Factor, $K_e$ : 1	
Solar Array Pressure Equalization Factor, $\gamma_a$ : 0.61	

**CALCULATION**

Velocity Pressure Due to Wind:  $q_h = 0.00256(K_z)(K_{zt})(K_d)(I)(V^2)$  (Ch 26. Eq 26.10 – 1)  
 Actual Uplift Pressure:  $p = 0.6D + 0.6W$  (Ch 2.4.1 LC #7/a)  
 Wind Uplift Pressure:  $p = q_h (GC_p)(\gamma_E)(\gamma_a)$  (Ch 29. Eq 29.4 – 7)

**Landscape / Portrait Panels**

Roof Zone	1	2e	2n	2r	3e	3r
Mount Spacing	67.8"	67.8"	67.8"	67.8"	67.8"	67.8"
External Pressure Coefficient ( $GC_p$ )	-1.78	-1.78	-1.98	-1.78	-2.47	-1.98
Actual Uplift Pressure (p)	-16 psf	-16 psf	-16 psf	-16 psf	-16 psf	-16 psf
Tributary Area (AT)	10.5 sqft	10.5 sqft	10.5 sqft	10.5 sqft	10.5 sqft	10.5 sqft
Uplift Force (P)	-167.99 lbs	-167.99 lbs	-167.99 lbs	-167.99 lbs	-167.99 lbs	-167.99 lbs

**Uplift Capacity**

Attachment Type = 4 pcs of #14 Wood Screw TopSpeed Mount Assembly	Hardware Pullout Capacity = 258 lbs
Embedment Depth = 0.5 in	Safety Factor = 1.5
	Duration Factor = 1.6

Maximum Uplift Force = 167.993 lbs

Allowable Pullout Capacity = 258 lbs

Allowable Pullout Capacity = 258 lbs > Uplift Force per Bolt = 167.99 lbs, Therefore OK.

Project Roof Mounted Solar PV Installation Property Owner Jeremiah Frueauf

Address 7013 Poplar Ave, Takoma Park, MD 20912, USA

I reviewed the design of the photovoltaic (PV) system, as designed by the manufacturer, and the design criteria utilized for the mounting equipment and panel mounting assembly (rack system) for the installation of (14) panels supported by the rack system, as shown on the drawings prepared for the above referenced address. I certify that the configurations and design criteria meet the standards and requirements of the International Residential Code (IRC) in COMCOR 08.00.02.

The attachment of the rack system to the building at the above address, including the location, number, and type of attachment points; the number of fasteners per attachment point; and the specific type of fasteners (size, diameter, length, minimum embedment into structural framing, etc.) meets the standards and requirements of the IRC adopted by Montgomery County in COMCOR 08.00.02.

I evaluated the existing roof structure of the building at the above address and analyzed its capacity to support the additional loads imposed by the PV system. I certify that no structural modifications of the existing roof structure are required. The existing roof structure meets the standards and requirements of the IRC, adopted by Montgomery County in COMCOR 08.00.02, necessary to support the PV system.

I evaluated the existing roof structure of the building at the above address and analyzed its capacity to support the additional loads imposed by the PV system. Structural modifications of the existing roof structure are required. I certify that the roof structure, as modified on the drawings for this project, will support the additional loads imposed by the PV system. I further certify that design of the modified roof structure meets the standards and requirements of the IRC, adopted by Montgomery County in COMCOR 08.00.02.

I prepared or approved the construction documents for the mounting equipment, rack system, roof structure for this project.

**Re-installations:**

I certify that the reinstallation of the photovoltaic system (PV) as shown on the approved drawings for permit \_\_\_\_\_ (show original permit #) does not alter the approval under the permit or make the PV system, attachment to the building, and roof framing unsafe.

49993

Maryland PE License Number

Date December 19, 2025

Seal



Signature David C. Hernandez, PE  
Digitally signed by David C. Hernandez,  
Date: 2025.12.19 17:37:28 -05:00

PROFESSIONAL CERTIFICATION. I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND, LICENSE NO. 49993, EXP. 10/06/2026.  
12/19/25



Property Owners Name: Jeremiah Frueauf

Property Owners Address: 7013 Poplar Avenue, Takoma Park, MD 20912

Address of Installation if different than owner's address:

---

I certify that:

- I prepared or approved the electrical drawings and related documents for the photovoltaic (PV) system at the above location.
  
- The design of the PV System, and all the electrical Installations and equipment, meets the standards and requirements of the National Electrical Code as adopted by Montgomery County in COMCOR 17.02.01
  
- I reviewed and completed the Worksheet for PV System, which was attached to the permit application for the PV system at the above location.

40780-State of MD Master Electrician License

Santos M. Andrade

Signature: 

Date: 01//06/2026

# City of Takoma Park

Housing and Community Development Department

Main Office 301-891-7119  
Fax 301-270-4568  
www.takomaparkmd.gov



7500 Maple Avenue  
Takoma Park, MD 20912

## MUNICIPALITY LETTER

January 07, 2026

**To:** Jeremiah Frueauf  
7013 Poplar Avenue, Takoma Park, MD 20912  
fru1shop@gmail.com 703-919-6064

**To:** Department of Permitting Services  
2425 Reedie Drive, 7<sup>th</sup> floor  
Wheaton, Maryland 20902

**From:** Planning and Development Services Division

### **THIS IS NOT A PERMIT – For Informational Purposes Only**

VALID FOR ONE YEAR FROM DATE OF ISSUE

The property owner is responsible for obtaining all required permits from Montgomery County and the City of Takoma Park. If this property is in the **Takoma Park Historic District**, it is subject to Montgomery County Historic Preservation requirements.

**Representative Name:** Tina Crouse-SEW tcrouse@solarenergyworld.com 410-570-4157

**Location of Project:** 7013 Poplar Avenue, Takoma Park, MD 20912

**Proposed Scope of Work:** Install (14) roof mounted solar panels, 5.67 kW

The purpose of this municipality letter is to inform you that the City of Takoma Park has regulations and city permit requirements that may apply to your project. This municipality letter serves as notification that, in addition to all Montgomery County requirements, you are required to comply with all City permitting requirements, including:

- Tree Impact Assessment/Tree Protection Plan
- Stormwater management
- City Right of Way

Failure to comply with these requirements could result in the issuance of a Stop Work Order and other administrative actions within the provisions of the law. Details of Takoma Park's permit requirements are attached on page 2.

The issuance of this letter does not indicate approval of the project nor does it authorize the property owner to proceed with the project. The City retains the right to review and comment on project plans during the Montgomery County review process.

# City Of Takoma Park

## The City of Takoma Park permits for the following issues:

### Tree Impact Assessment/Tree Protection Plan/Tree Removal Application:

Construction activities that occur within 50 feet of any urban forest tree (7 and 5/8" in trunk diameter or greater), located on the project property or on an adjacent property, may require a Tree Impact Assessment and possibly a Tree Protection Plan Permit. Make sure to submit a request for a Tree Impact Assessment and schedule a site visit with the City's Urban Forest Manager if any urban forest tree is in the vicinity of proposed construction activities. See the Tree Permits section of the City website for the specific conditions in which a Tree Impact Assessment is required. Depending on the Urban Forest Manager's conclusion following the Tree Impact Assessment, you may need to prepare a full Tree Protection Plan and apply for a Tree Protection Plan Permit as well. Separately, the removal of any urban forest tree will require a Tree Removal Permit application. The tree ordinance is detailed in the City Code, section 12.12. For permit information check: <https://takomaparkmd.gov/services/permits/tree-permits>. The City's Urban Forest Manager can be reached at 301-891-7612 or [urbanforestmanager@takomaparkmd.gov](mailto:urbanforestmanager@takomaparkmd.gov).

### Stormwater Management:

If you plan to develop or redevelop property, you may be required to provide appropriate stormwater management measures to control or manage runoff, as detailed in City Code section 16.04. All commercial or institutional development in the city must apply for a Stormwater Management Permit regardless of the size of the land disturbance. Additions or modifications to existing detached single-family residential properties do not require a Stormwater Management permit if the project does not disturb more than 5,000 square feet of land area. For more information visit: <https://takomaparkmd.gov/government/public-works/stormwater-management-program/>. The City Engineer should be contacted to determine if a City permit is required. The City Engineer can be reached at 301-891-7620.

### City Right of Way:

- To place a **construction dumpster or storage container** temporarily on a City right of way (usually an adjacent road), you will need to obtain a permit. A permit is not required if the dumpster is placed in a privately-owned driveway or parking lot.
- If you plan to install a new **driveway apron**, or enlarge or replace an existing driveway apron, you need a Driveway Apron Permit.
- If you plan to construct a **fence** in the City right of way, you need to request a Fence Agreement. If approved, the Agreement will be recorded in the Land Records of Montgomery County.

For more information and applications for City permits, see: <https://takomaparkmd.gov/services/permits/> or contact the Department of Public Works at 301-891-7633.

**Failure to comply with the City's permitting requirements could result in the issuance of a Stop Work Order and other administrative actions within the provisions of the law.**

eSigned via GovOS.com  
*Tina Crouse*  
Key: 38b2056622713c0b979aa7ee94776a

Tina Crouse

01-06-2026

eSigned via GovOS.com  
*Takoma Park Planning Division*  
Key: 19fe84f123e68a3ff4576219059d5f8e

01-07-2026



# Mounting Systems, Mounting Devices, Clamping Devices and Ground Lugs for Use with Photovoltaic Modules and Panels

**COMPANY**

**SUNRUN SOUTH LLC, DBA SNAPNRACK**

775 Fiero Ln

Suite 200

San Luis Obispo, CA 93401 United States

E359313

Cat. No.	Investigated for Bonding	Investigated for Mechanical Loading	System Fire Classification (A, B or C)	Tested in Combination With
Photovoltaic mounting system				

<p>Series 200 - Consisting of the Following Components:                  Kee Klamp Tee, Speed Rail Tee, Speed Rail Single Swivel, Threaded Pipe Coupler, Pipe Clamp Assembly, Ground Rail, Mid Clamp, X End Clamp, Universal End Clamp, Speed Rail Tee – 2" Posts, Speed Rail Single Swivel – 2" Posts, Speed Rail Cross Assembly for 2" Posts, Ground Rail Splice Clamp</p>	<p>Y*</p>	<p>Y – Minimum mechanical load ratings defined by UL 2703 for all modules listed</p>	<p>N</p>	<p>Listed PV Modules, where XXX is the wattage value. All wattage values are covered:</p> <p>Aptos Solar:                  DNA-120-MF23-XXX                  DNA-120-BF23-XXX                  DNA-144-MF23-XXX                  DNA-144-BF23-XXX                  DNA-120-MF26-XXXW, DNA-120-MF26-XXXW, DNA-144-MF26-XXXW                  DNA-120-BF26-XXXW                  DNA-144-BF26-XXXW</p> <p>Boviet Solar:                  BVM6610P-XXX                  BVM6610M-XXX                  BVM6612P-XXX                  BVM6612M-XXX                  BVM7612M-XXX-H-HC-BF-DG</p> <p>Canadian Solar:                  CS6K-XXX-M                  CS6K-XXX-M-SD                  CS6K-XXX-P                  CS6K-XXX-P-SD                  CS6K-XXX-MS                  CS6P-XXX-M                  CS6P-XXX-P                  CS6P-XXX-P-SD                  CS6V-XXX-M                  CS3W-XXX-P                  CS6V-XXX-P                  CS6X-XXX-P                  CS3K-XXX-P                  CS3K-XXX-MS                  CS3U-XXX-MS                  CS3U-XXX-P                  CS1K-XXX-MS                  CS1H-XXX-MS                  CS1H-XXX-MS-AB                  CS3N-XXX-MS                  CS1Y-XXX-MS                  CS6.1-54TM-XXXH                  CS3W-XXXMB-AG                  CS3Y-XXXMB-AG                  CS6W-XXXMB-AG                  CS6R-XXXMS-HL                  CS3W-xxxMS                  CS3W-xxxP, where xxx is 385 to 450</p> <p>CertainTeed -                  CTXXXHC11-06,                  CTXXXHC11-06,                  CTM10XXXHC11-06</p> <p>Chint Solar:                  CHSM6612M-XXX                  CHSM6612M/HV-XXX                  CHSM6612M(BL)-XXX                  **CHSM72M-HC-XXX (Astro 4)                  **CHSM72M-HC-XXX (Astro 5)</p>
--	-----------	--	----------	--

Crossroads Solar:  
Crossroads Solar xxx

Dehui Solar:  
DH-M760B-XXXW  
DH-M760W-XXXW  
DH-M772W-XXXW  
DH-M760F-XXXW  
DH-M772F-XXXW

ET Solar:  
ET-P660XXXBB  
ET-P660XXXWB  
ET-P660XXXWW  
ET-P660XXXWWG  
P660XXXWB/WW  
P660XXXWWG  
M660XXXBB  
M660XXXWW  
Freedom Forever Procurement:  
FF-MP-BBB-xxx, where xxx is 365 to 410.

Hansol Technics  
HAXXXAA-NNEA0  
where XXX is 420 to 440

Hanwha/Q Cells:  
Q.PEAK BLK-G3.1-XXX  
Q.PEAK G3.1-XXX  
Q.PLUS BFR-G3.1-XXX  
B.LINE PLUS BFR-G4.1-XXX  
B.LINE PRO BFR-G4.1-XXX  
Q.BASE GY-XXX  
Q.PEAK BFR-G4-XXX  
Q.PEAK BFR-G4.1-XXX  
Q.PEAK BLK-G4.1-XXX  
Q.PEAK BLK-G4.1/TAA-XXX  
Q.PEAK G4-XXX  
Q.PEAK G4.1-XXX  
Q.PEAK G4.1/MAX-XXX  
Q.PEAK G4.1/TAA-XXX  
Q.PLUS BFR-G4-XXX  
Q.PLUS BFR-G4.1-XXX  
Q.PLUS BFR-G4.1/TAA-XXX  
Q.PLUS G4-XXX  
Q.PLUS GY-XXX  
Q.PLUS BFR-GY-XXX  
Q.PRO BFR-G4-XXX  
Q.PRO BFR-G4.1-XXX  
Q.PRO BFR-G4.3-XXX  
Q.PRO BFR-GY-XXX  
Q.PRO BLK-GY-XXX  
Q.PRO G4-XXX  
Q.PRO GY-XXX  
Q.PRO GY/SC-XXX  
Q.PEAK DUO-G6+-XXX  
Q.PEAK DUO-BLK-G6+-XXX  
Q.PEAK DUO-G6-XXX  
Q.PEAK DUO-BLK-G6-XXX  
Q.PEAK DUO-G8+-XXX  
Q.PEAK DUO-BLK-G8+-XXX

<p>UR-40 Mounting and Bonding Systems for use with Photovoltaic Modules, consisting of the following components: UR-40 Rail, Mid Clamp, X End Clamp, Universal End Clamp, UR-40 Splice, UR-40 Composition Mount Kits, SpeedSeal Foot Mount Kit, SpeedSeal Deckfoot Mount Kit for UR-40, Standard Standoff for UR-40, Four Hole Standoff for UR-40, Heavy Duty Standoff for UR-40, OmniBase Standoff for UR-40, Metal Roof Base Standoff for UR-40, UR-40 Corrugated Block, Standard Base Seam Clamp for UR-40, Wide Base Seam Clamp for UR-40, UR-40 Universal Tile Hook, UR-40 Flat Tile Hook, UR-40 Tile Hook F, UR-40 Tile Hook WS, Flat Tile Replacement Kit for UR-40, S Tile Replacement Kit for UR-40, W Tile Replacement Kit for UR-40, UR-40 Hanger Bolt Clamp, UR-40 Tilt Kits, SnapNrack Ground Lug Models 242-02101 or 242-92202, IlSCO Ground Lug Models GBL-4DBT or SGB-4, UR-40 Skirt Assembly, MLPE Frame Attachment Kit, MLPE Rail Attachment Kit, Smart Clips, Tilt Kits, Seam Clamp Simple Tilt Kits, Adjustable Tile Hook, OmniShield</p>	<p>Y*</p>	<p>Y – Minimum mechanical load ratings defined by UL 2703 for all modules listed</p>	<p>Y – Class A with and without skirt assembly for Type 1, Type 2 and Type 29 modules</p>	<p>Q.PEAK DUO-G8-XXX                  Q.PEAK DUO-BLK-G8-XXX                  Q.PLUS L-G4-XXX                  Q.PLUS L-G4.1-XXX                  Q.PLUS L-G4.2-XXX                  Q.PEAK L-G4.1-XXX                  Q.PEAK L-G4.2-XXX                  Q.PLUS DUO-L-G5-XXX                  Q.PLUS DUO-L-G5.1-XXX                  Q.PLUS DUO-L-G5.2-XXX                  Q.PLUS DUO-L-G5.3-XXX                  Q.PEAK DUO-L-G5.2-XXX                  Q.PEAK DUO-L-G5.3-XXX                  Q.PEAK DUO-L-G7-XXX                  Q.PEAK DUO-L-G7.1-XXX                  Q.PEAK DUO-L-G7.2-XXX                  Q.PEAK DUO-L-G7.3-XXX                  Q.PEAK DUO-L-G6-XXX                  Q.PEAK DUO-L-G6.2-XXX                  Q.PEAK DUO-L-G6.3-XXX                  Q.PEAK DUO-L-G8-XXX                  Q.PEAK DUO-L-G8.1-XXX                  Q.PEAK DUO-G5-XXX                  Q.PEAK DUO-BLK-G5-XXX                  Q.PLUS DUO-G5-XXX                  Q.PEAK DUO-G7-XXX                  Q.PEAK DUO-BLK-G7-XXX                  Q.PEAK DUO-G7.2-XXX                  Q.PEAK DUO BLK-G6+/AC-XXX                  Q.PEAK DUO-ML-G9-XXX                  Q.PEAK DUO BLK-G5/TS-XXX                  Q.PEAK DUO G6+/TS-XXX                  Q.PEAK DUO BLK-G6+/TS-XXX                  Q.PEAK DUO XL-G9.3-XXX                  Q.PEAK DUO-L-G8.2-XXX                  Q.PEAK DUO-L-G8.3-XXX                  Q.PEAK DUO-G5/SC-XXX                  Q.PEAK DUO-BLK-G5/SC-XXX                  Q.PEAK DUO-G6+/SC-XXX                  Q.PEAK DUO-BLK-G6+/SC-XXX                  Q.PEAK DUO-BLK-ML-G9-XXX                  Q.PEAK DUO-G5/TS-XXX                  Q.PEAK DUO-G6/TS-XXX                  Q.PEAK DUO BLK-G6/TS-XXX                  Q.PEAK DUO XL-G9.2-XXX                  Q.PEAK DUO BLK-G9-XXX                  Q.PEAK DUO ML-G9+-XXX                  Q.PEAK DUO BLK-G9+-XXX                  Q.PEAK DUO BLK ML-G9+-XXX                  Q.PEAK DUO XL-G10.2-XXX                  Q.PEAK DUO XL-G10.3-XXX                  Q.PEAK DUO XL-G10.d-XXX                  Q.PEAK DUO L-G8.3/BGT-XXX                  Q.PEAK DUO BLK ML-G10+-XXX                  Q.PEAK DUO BLK ML-G10-XXX                  Q.PEAK DUO BLK ML-G10.a+-XXX                  Q.PEAK DUO BLK ML-G10.a-XXX                  Q.PEAK DUO XL-G9.3/BFG-XXX                  Q.PEAK DUO XL-G10.3/BFG-XXX                  Q.PEAK DUO XL-G10.c-XXX                  Q.PEAK DUO L-G8.3/BFG-XXX                  Q.TRON_XL-G2.3/BFG-XXX</p>
---	-----------	--	---	--

Q.PEAK DUO ML-G10-XXX  
Q.PEAK DUO ML-G10+-XXX  
Q.PEAK DUO ML-G10.a+-XXX  
Q.PEAK DUO ML-G10.a-XXX  
Q.PEAK DUO BLK ML-G10.a+/TS-XXX,  
Q.PEAK DUO G10-XXX, Q.PEAK DUO BLK-  
G10-XXX, Q.PEAK DUO G10+-XXX, Q.PEAK  
DUO BLK-G10+-XXX  
Q.TRON-G1+ XXX  
Q.TRON BLK-G1+ XXX  
Q.PEAK DUO BLK G10+/AC XXX  
Q.PEAK DUO BLK G10+/HL XXX  
Q.PEAK DUO XL-G11.3 XXX  
Q.PEAK DUO XL-G11.3 BFG XXX  
Q.Tron BLK M-G2+ XXX,  
Q.Tron M-G2+ XXX,  
Q.PEAK DUO BLK ML-G10+/t XXX  
Q.PEAK DUO XL-G10.d/BFG  
Q.TRON BLK M-G2+/AC XXX

## HT-SAAE:

HT60-166M-XXX where XXX is 340-390;  
HT60-182M-XXX

## Hanwha Solar One:

HSL60P6-PB-2-XXXQ  
HSL60P6-PB-4-XXXQ

## Heliene:

60M-XXX  
60P-XXX  
72M-XXX  
72P-XXX

## Runergy:

HY-DH108N8  
HY-DH108P8-XXX(Y)  
HY-DH144N8  
HY-DH144P8

## Hyundai:

HiS-MXXXRG  
HiS-SXXXRG  
HiS-SXXXRW  
HiA-SXXXMS  
HiS-MXXXMG  
HiS-SXXXMG  
HiD-SXXXRG  
HiS-SXXXXY  
HiS-SXXXXYI  
HiS-SxxxYH  
HiN-SxxxXG(BK)  
All may be followed by (BK)

## JA Solar:

JAM6-60-XXX/SI  
JAP6-60-XXX/3BB  
JAM60S09-XXX/PR  
JAM60S10-XXX/MR  
JAM60S10-XXX/PR  
JAM60S12-XXX/PR  
JAM60S17-XXX/MR

JAP72S01-XXX/SC  
JAM72S09-XXX/PR  
JAM72S10-XXX/MR  
JAM72S10-XXX/PR  
JAM72S12-XXX/PR  
JAP6(k)-72-XXX/4BB  
JAM54S30-XXX/MR where XXX is 400-410,  
JAM54S31-XXX/MR  
JAM72D30-XXX/MB  
JAM72D10-XXX/MB

Jinko Solar:

JKMXXXM-60  
JKMXXXP-60  
JKMXXXP-60-J4  
JKMXXXP-60-V  
JKMXXXP-60B-J4  
JKMXXXPP-60  
JKMXXXPP-60-V  
JKMXXXM-60HL  
JKMXXXM-60L  
JKMXXXM-60HBL  
JKMXXXM-72  
JKMXXXP-72  
JKMXXXP-72-V  
JKMXXXPP-72  
JKMXXXPP-72-V  
JKMSXXXP-72  
JKMXXXM-72HL-V  
JKMXXXM-72HL-TV  
JKMXXXM-72L-V  
JKMXXXM-72HBL  
JKMXXXM-6TL3-B  
JKMXXXM-6RL3-B  
JKMXXXM-7RL3-V  
JKMXXXM-7RL3-TV  
JKMXXXM-72HL4-V  
JKMXXXM-72HL4-TV  
JKMXXXN-54HL4-B

KB Solar LLC:

MODULE-KBS-375-MONO  
MODULE-KBS-375-MONO-BF  
MODULE-KBS-450-MONO  
MODULE-KBS-450-MONO-BF

Kyocera:

KUXXX-6YYY  
KUXXX-8YYY

LG:

LGXXXN1C-A5  
LGXXXN1K-A5  
LGXXXQ1C-A5  
LGXXXQ1K-A5  
LGXXXS1C-A5  
LGXXXN2C-B3  
LGXXXN2W-B3  
LGXXXN1C-G4  
LGXXXN1K-G4  
LGXXXS1C-G4  
LGXXXN2C-G4

LGXXN2K-G4  
LGXXN2W-G4  
LGXXS2C-G4  
LGXXS2W-G4  
LGXXN1C-V5  
LGXXN1W-V5  
LGXXN2T-V5  
LGXXN2T-J5  
LGXXN1T-V5  
LGXXA1C-V5  
LGXXM1C-L5  
LGXXN1C-N5  
LGXXM1K-L5  
LGXXN1K-L5  
LGXXN1C-A6  
LGXXQ1C-A6  
LGXXM1K-A6  
LGXXA1C-A6  
LGXXN1K-A6  
LGXXN1W-A6  
LGXXQ1K-A6  
LGXXM1C-A6  
LGXXQAK-A6  
LGXXN2W-E6  
LGXXN1K-E6  
LGXXQAC-A6  
LGXXN1K-B6  
LGXXN2T-E6  
LGXXN3K-V6

Longi:

LR6-60-XXXM  
LR6-60BK-XXXM  
LR6-60HV-XXXM  
LR6-60PB-XXXM  
LR6-60PE-XXXM  
LR6-60PH-XXXM  
LR6-60HPB-XXXM  
LR6-60HPH-XXXM  
LR4-72HPH-XXXM  
LR4-60HIB-XXXM  
LR4-60HIH-XXXM  
LR4-60HPB-XXXM  
LR4-60HPH-XXXM  
LR6-60HIB-XXXM  
LR6-60HIH-XXXM  
LR5-54HPB-XXXM  
LR5-54HABB-XXXM

Maxon Solar Technologies, LTD.  
SPR-MAX3-XXX-BLK-R where xxx is 395-420

Meyer Burger:

Meyer Burger Black \*\*  
Meyer Burger White \*\*

Mission Solar:

MSEXXXSO5T  
MSEXXXSO5K  
MSEXXXSQ5T  
MSEXXXSQ5K

				<p>MSEXXXMM4J  MSEXXXMM6J  MSEXXXSO6W  MSEXXXSO4J  MSEXXXSO6J  MSEXXXSQ6S  MSEXXXSQ4S  MSEXXXSR8K  MSEXXXSR8T  MSEXXXSR9S  MSE60AXXX  MSEXXXTS60  MSEXXXSX5K  MSEXXXSX5T  MSEXXXSX6S  MSEXXXSX6W  TXI6-XXX120BB  MSExxxSX5R, where xxx is 375 to 390  TXI10-XXX108BB  MSEXXXHT0B  where XXX is 390 to 410  MSEXXXSX9R  where XXX is 380 to 400</p>
--	--	--	--	--

Mitrex Inc:  
Mxxx-I3H  
M390-A1F

Next Energy Alliance:  
USNEA-XXXM3-60  
USNEA-XXXM3B-60  
USNEA-XXXM3-72  
USNEA-XXXM3B-72

Panasonic:  
VBHNXXXKA01  
VBHNXXXKA02  
VBHNXXXSA16  
VBHNXXXKA03  
VBHNXXXKA04  
VBHNXXXSA17  
VBHNXXXSA18  
VBHNXXXSA17E  
VBHXXXRA18N  
VBHXXXRA03K  
EVPVXXXPK  
EVPVXXXHK  
EVPVXXXHK2 where XXX is 420 to 430

Phono Solar:  
PSXXXM-20/U  
PSXXXMH-20/U  
PSxxxM8GF-24/TH where xxx is 520 to 550,  
PSxxxM8GFH-24/TH, where xxx is 520 to 550,  
PSxxxM8GF-18/VH, where xxx is 390 to 410,  
PSxxxM8GFH-18/VH, where xxx is 390 to 410,  
PSxxxM6-24/TH, where xxx is 510 to 550.

REC:  
RECXXXPE

<p>UR-60 Mounting and Bonding Systems for use with Photovoltaic Modules, consisting of the following components: UR-60 Rail, Mid Clamp, X End Clamp, Universal End Clamp, UR-60 Splice, UR-60 Composition Mount Kits, SpeedSeal Foot Mount Kit, Standard Standoff for UR-60, Four Hole Standoff for UR-60, Heavy Duty Standoff for UR-60, OmniBase Standoff for UR-60, Metal Roof Base Standoff for UR-60, UR-60 Corrugated Block, Standard Base Seam Clamp for UR-60, Wide Base Seam Clamp for UR-60, UR-60 Universal Tile Hook, UR-60 Flat Tile Hook, UR-60 Tile Hook F, UR-60 Tile Hook WS, Flat Tile Replacement Kit for UR-60, S Tile Replacement Kit for UR-60, W Tile Replacement Kit for UR-60, UR-60 Hanger Bolt Clamp, UR-60 Tilt Kits, SnapNrack Ground Lug Models 242-02101 or 242-92202, IlSCO Ground Lug Models GBL-4DBT or SGB-4, UR-40 Skirt Assembly, MLPE Frame Attachment Kit, MLPE Rail Attachment Kit, Smart Clips, Tilt Kits, Adjustable Tile Hook.</p>	<p>Y*</p>	<p>Y – Minimum mechanical load ratings defined by UL 2703 for all modules listed</p>	<p>Y – Class A with and without skirt assembly for Type 1, Type 2 and Type 29 modules</p>	<p>RECXXXPE-BLK                  RECXXXTP                  RECXXXTP-BLK                  RECXXXTP IQ                  RECXXXTP2                  RECXXXTP2-BLK                  RECXXXNP                  RECXXXTP2M                  RECXXXTP72                  RECXXXPE72                  RECXXXPE72XV                  RECXXXTP2M 72                  RECXXXTP2M 72 BLK                  RECXXXTP2M 72 BLK2                  RECXXXTP2SM 72                  RECXXXTP2SM 72 BLK                  RECXXXTP2SM 72 BLK2                  RECXXXAA                  RECXXXTP3                  RECXXXTP3M                  RECXXXTP4                  RECXXXAA Pure                  RECXXXNP2                  RECxxxAA PURE 2                  RECxxxAA PURE-RX</p> <p>- All may be followed by BLK or BLACK</p> <p>Renesola:                  JCXXXM-24/Bb                  JCXXXM-24/BBh</p> <p>SEG Solar:                  SEG-XXX-BMB-HV,                  SEG-xxx-BMB-TB                  SEG-xxx-BMD-HV &amp;                  SEG-xxx-BMD-TB,                  where xxx can be 370-425                  SEG-XXX-BTD-BG where xxx is 420-435</p> <p>Silfab:                  SLAXXX-M                  SLAXXX-P                  SSAXXX-M                  SSAXXX-P                  SLGXXX-M                  SLGXXX-P                  SSGXXX-M                  SSGXXX-P                  SILXXXBL                  SILXXXML                  SILXXXNT                  SILXXXHL                  SILXXXNL                  SILXXXBK                  SILXXXNX                  SILXXXNU                  SILXXXHC                  SILXXXHN                  SILXXXBG                  SILXXXQD                  SILXXXQM</p>
---	-----------	--	---	---

SIL-xxxHC+,  
SIL-xxxHM.

S-Energy:  
SL65-54BGJ-XXXV  
SL65-54BHJ-XXXV

Solaria:  
Solaria PowerXT-XXXR-PX  
Solaria PowerXT-XXXR-BX  
Solaria PowerXT-XXXR-AC  
Solaria PowerXT-XXXR-PM  
Solaria PowerXT-XXXR-PM-AC

SolarJuice (Solar4America)  
S4AXXX72H5BB,  
S4AXXX72H5BW,  
S4AXXX72M5BB,  
S4AXXX72M5BW,  
where XXX is 375-420.  
S4AXXX60M5BB,  
S4AXXX60M5BW,  
S4AXXX60H5BB,  
S4AXXX60H5BW,  
where XXX is 320-345.  
S4AXXX-108MH10SB,  
S4AXXX-108MH10SW,  
S4AXXX-108MH10BB,  
S4AXXX-108MH10BW,  
Where XXX is 385-410.  
S4AXXX-108TH10BB  
where XXX is 425 to 440  
S4AXXX-144MH10STT,  
S4AXXX-144MH10BTT,  
where XXX is 530-565.  
S4AXXX-144TH10STT  
S4AXXX-144TH16STT  
where XXX is 565 to 590

SolarWorld:  
SWXXX-Mono  
SWXXX-Mono XL

Suniva:  
MVX-XXX-60-5-701  
MVX-XXX-60-5-7B1  
OPT-XXX-60-4-100  
OPT-XXX-60-4-1B0  
OPT-XXX-60-4-800  
OPT-XXX-60-4-8B0

Sunpower:  
SPR-EYY-XXX  
SPR-EYY-XXX  
SPR-XYX-XXX  
SPR-XYX-XXX  
SPR-AXXX-G-AC  
SPR-AXXX  
SPR-AXXX-BLK-G-AC  
SPR-AXXX-BLK  
SPR-MXXX-H-AC  
SPR-MXXX

SPR-MXXX-BLK-H-AC  
SPR-MXXX-BLK

SunSpark:  
SST-XXXM3-60  
SST-XXXM3B-60  
SST-XXXM3-72  
SST-XXXM3B-72

Talesun:  
TP660M-XXX  
TP660P-XXX  
TP672M-XXX  
TP672P-XXX

Tesla:  
TXXXS  
TXXXH

Trina:  
TSM-XXXDD05(II)  
TSM-XXXDD05A.05(II)  
TSM-XXXDD05A.08(II)  
TSM-XXXDD05A.082(II)  
TSM-XXXPA05  
TSM-XXXPA05.05  
TSM-XXXPA05.08  
TSM-XXXPD05  
TSM-XXXPD05.002  
TSM-XXXPD05.05  
TSM-XXXPD05.05S  
TSM-XXXPD05.08  
TSM-XXXPD05.082  
TSM-XXXPD05.08D  
TSM-XXXPD05.08S  
TSM-XXXDD05H.05(II)  
TSM-XXXDD06M.05(II)  
TSM-XXXDE15H(II)  
TSM-XXXDE15M(II)  
TSM-XXXDE06X.05(II)  
TSM-XXXDE09.05  
TSM-XXXDE15V(II)  
TSM-XXXDE19  
TSM-XXXDEG15VC.20(II)  
TSM-XXXDEG18MC.20(II)  
TSM-XXXDEG19C.20  
TSM-XXXDEG21C.20  
TSM-XXXDE09C.05  
TSM-XXXDE09C.07

URECO  
FAMxxxE7G-BB  
FBMxxxMFG-BB

Vikram Solar:  
Somera VSMHBB.60.XXX.05  
SOMERA VSMH.72.XXX.05  
PREXOS VSMDHT.60.XXX.05  
PREXOS VSMDHT.72.XXX.05

VSUN Solar:  
VSUNXXX-144BMH-DG,

VSUNXXX-120BMH,  
 VSUNXXX-108BMH  
 VSUNXXX-132BMH where xxx is 475-520

Yingli:  
 YLXXXA-29b  
 YLXXXP-29b

ZNShine:  
 ZXM6-60-XXX/M  
 ZXM6-NH120-XXXM, ZXM6-NH144-XXXM  
 ZXM7-SH108-XXX/M  
 \*\*ZXM7-SHLDD144-XXX/M

REC Solar, model  
 RECxxxAA Pure-R, where  
 xxx can be 390-430

REC Solar, model  
 RECxxxNP3, where xxx  
 can be 380-410

Trina Solar, model  
 TSM-xxxNE09RC.05,  
 where xxx can be 365-430

Aptos Solar, model  
 DNA-108-MF10-xxxW, where  
 xxx can be 390-415

NRTL Listed Module Level Power  
 Electronics:

Rapid Shutdown Devices:

AP Smart:  
 Model RSD-S-PLC

Celestica International:  
 DG-006-F001201x  
 DG-006-F001401x

Delta Electronics:  
 GPI00010105

Ginlong Technologies:  
 Solis-RSD-1G  
 Solis-MLRSD-R1-1G  
 Solis-MLRSD-R2-1G

SMA:  
 RSB-2S-US-10

Microinverters:

Enphase:  
 M250  
 M215  
 C250  
 IQ6-60-2-US  
 IQ6PLUS-72-2-US  
 IQ7-60-2-US

<p>UR-45 Mounting and Bonding System for use with Photovoltaic Modules. All components are interchangeable between the UR-40 and UR-45 except for the UR-45 specific UR-45 Rail.</p>	<p>Y*</p>	<p>Y – Minimum mechanical load ratings defined by UL 2703 for all modules listed</p>	<p>Y – Class A with and without skirt assembly for Type 1, Type 2 and Type 29 modules</p>	<p>IQ7-60-B-US                  IQ7PLUS-72-2-US                  IQ7PLUS-72-B-US                  IQ8-60                  IQ8PLUS-72                  IQ8A-72                  IQ8H-208-72                  IQ8H-240-72</p> <p>Optimizers:</p> <p>Generac – Optimizer model S2502</p> <p>Lunar Energy – Lunar Optimizer</p> <p>SolarEdge:                  P300-5NC4ARS                  P320-5NC4ARS                  P370-5NC4AFS                  P400-5NC4AFS                  P320                  P340                  P370                  P400                  P401                  P405                  P485                  P505                  P730                  P800p                  P850                  P860                  P950                  S440                  S500                  P1100                  P1101</p> <p>Monitoring Devices:</p> <p>Tigo:                  TS4-R-F                  TS4-R-M                  TS4-R-O                  TS4-R-S                  TS4-R-M-DUO                  TS4-R-O-DUO                  TS4-R-S-DUO                  TS4-A-F                  TS4-A-2F                  TS4-A-O                  TS4-A-S</p> <p>Philadelphia Solar:                  **PS-M144(HCBF)-XXXW                  PS-M108(HCBF)0XXXW</p> <p>PS-M108(HC)-XXXW                  PS-M144(HC)-XXXW</p> <p>Thornova:</p>
--	-----------	--	---	--

11/19/24, 4:30 PM

QIMS.E359313 - Mounting Systems, Mounting Devices, Clamping Devices and Ground Lugs for Use with Photovoltaic Modules a...

TS-BB54(XXX)
TS-BB60(XXX)
**TS- BG54(XXX)
TS-BG60(XXX)
**TS-BG72(XXX)

<p>MightyMount Comp-S consisting of the following: Comp-S Track, Ultra Rail Mid Clamp, Ultra Rail End Clamp, Wire Management Clips, Ground Lugs, MLPE Rail Attachment Kit and MLPE Frame Attachment Kit.</p>	<p>Y</p>	<p>N</p>	<p>Y – Class A with and without skirt assembly for Type 1, Type 2 and Type 29 modules</p>	
--	----------	----------	---	--

11/19/24, 4:30 PM

QIMS.E359313 - Mounting Systems, Mounting Devices, Clamping Devices and Ground Lugs for Use with Photovoltaic Modules a...

--	--	--	--	--

<p>MightyMount – Metal-T consisting of the following: Track, Short Leg, Tall Leg, Pinned Channel Nut, Ultra Rail Mid Clamp, Ultra Rail End Clamp, Wire Management Clips, Ground Lugs, MLPE Rail Attachment Kit and MLPE Frame Attachment Kit, OmniShield.</p>	<p>Y</p>	<p>N</p>	<p>Y – Class A when mounted with Type 1, 2 or 3 modules per Exception of 11.1 of UL 2703</p>	<p>Listed PV Modules, where XXX is the wattage value. All wattage values are covered:</p> <p>Aptos Solar:  DNA-120-MF23-XXX  DNA-120-BF23-XXX  DNA-144-MF23-XXX  DNA-144-BF23-XXX  DNA-120-MF26-XXXW, DNA-120-MF26-XXXW, DNA-144-MF26-XXXW  DNA-120-BF26-XXXW  DNA-144-BF26-XXXW</p> <p>Boviet Solar:  BVM6610P-XXX  BVM6610M-XXX  BVM6612P-XXX  BVM6612M-XXX  BVM7612M-XXX-H-HC-BF-DG</p> <p>Canadian Solar:  CS6K-XXX-M  CS6K-XXX-M-SD  CS6K-XXX-P  CS6K-XXX-P-SD  CS6K-XXX-MS  CS6P-XXX-M  CS6P-XXX-P  CS6P-XXX-P-SD  CS6V-XXX-M  CS3W-XXX-P  CS6V-XXX-P  CS6X-XXX-P  CS3K-XXX-P  CS3K-XXX-MS  CS3U-XXX-MS  CS3U-XXX-P  CS1K-XXX-MS  CS1H-XXX-MS  CS1H-XXX-MS-AB  CS3N-XXX-MS  CS1Y-XXX-MS  CS6.1-54TM-XXXH  CS3W-XXXMB-AG  CS3Y-XXXMB-AG  CS6W-XXXMB-AG  CS6R-XXXMS-HL  CS3W-xxxMS  CS3W-xxxP, where xxx is 385 to 450</p> <p>CertainTeed -  CTXXXHC11-06,  CTXXXHC11-06,  CTM10XXXHC11-06</p> <p>Chint Solar:  CHSM6612M-XXX  CHSM6612M/HV-XXX  CHSM6612M(BL)-XXX  **CHSM72M-HC-XXX (Astro 4)  **CHSM72M-HC-XXX (Astro 5)</p>
---	----------	----------	--	--

Crossroads Solar:  
Crossroads Solar xxx

Dehui Solar:  
DH-M760B-XXXW  
DH-M760W-XXXW  
DH-M772W-XXXW  
DH-M760F-XXXW  
DH-M772F-XXXW

ET Solar:  
ET-P660XXXBB  
ET-P660XXXWB  
ET-P660XXXWW  
ET-P660XXXWWG  
P660XXXWB/WW  
P660XXXWWG  
M660XXXBB  
M660XXXWW

Freedom Forever Procurement:  
FF-MP-BBB-xxx, where xxx is 365 to 410.

Hansol Technics  
HAXXXAA-NNEA0  
where XXX is 420 to 440

Hanwha/Q Cells:  
Q.PEAK BLK-G3.1-XXX  
Q.PEAK G3.1-XXX  
Q.PLUS BFR-G3.1-XXX  
B.LINE PLUS BFR-G4.1-XXX  
B.LINE PRO BFR-G4.1-XXX  
Q.BASE GY-XXX  
Q.PEAK BFR-G4-XXX  
Q.PEAK BFR-G4.1-XXX  
Q.PEAK BLK-G4.1-XXX  
Q.PEAK BLK-G4.1/TAA-XXX  
Q.PEAK G4-XXX  
Q.PEAK G4.1-XXX  
Q.PEAK G4.1/MAX-XXX  
Q.PEAK G4.1/TAA-XXX  
Q.PLUS BFR-G4-XXX  
Q.PLUS BFR-G4.1-XXX  
Q.PLUS BFR-G4.1/TAA-XXX  
Q.PLUS G4-XXX  
Q.PLUS GY-XXX  
Q.PLUS BFR-GY-XXX  
Q.PRO BFR-G4-XXX  
Q.PRO BFR-G4.1-XXX  
Q.PRO BFR-G4.3-XXX  
Q.PRO BFR-GY-XXX  
Q.PRO BLK-GY-XXX  
Q.PRO G4-XXX  
Q.PRO GY-XXX  
Q.PRO GY/SC-XXX  
Q.PEAK DUO-G6+-XXX  
Q.PEAK DUO-BLK-G6+-XXX  
Q.PEAK DUO-G6-XXX  
Q.PEAK DUO-BLK-G6-XXX  
Q.PEAK DUO-G8+-XXX  
Q.PEAK DUO-BLK-G8+-XXX

- Q.PEAK DUO-G8-XXX
- Q.PEAK DUO-BLK-G8-XXX
- Q.PLUS L-G4-XXX
- Q.PLUS L-G4.1-XXX
- Q.PLUS L-G4.2-XXX
- Q.PEAK L-G4.1-XXX
- Q.PEAK L-G4.2-XXX
- Q.PLUS DUO-L-G5-XXX
- Q.PLUS DUO-L-G5.1-XXX
- Q.PLUS DUO-L-G5.2-XXX
- Q.PLUS DUO-L-G5.3-XXX
- Q.PEAK DUO-L-G5.2-XXX
- Q.PEAK DUO-L-G5.3-XXX
- Q.PEAK DUO-L-G7-XXX
- Q.PEAK DUO-L-G7.1-XXX
- Q.PEAK DUO-L-G7.2-XXX
- Q.PEAK DUO-L-G7.3-XXX
- Q.PEAK DUO-L-G6-XXX
- Q.PEAK DUO-L-G6.2-XXX
- Q.PEAK DUO-L-G6.3-XXX
- Q.PEAK DUO-L-G8-XXX
- Q.PEAK DUO-L-G8.1-XXX
- Q.PEAK DUO-G5-XXX
- Q.PEAK DUO-BLK-G5-XXX
- Q.PLUS DUO-G5-XXX
- Q.PEAK DUO-G7-XXX
- Q.PEAK DUO-BLK-G7-XXX
- Q.PEAK DUO-G7.2-XXX
- Q.PEAK DUO BLK-G6+/AC-XXX
- Q.PEAK DUO-ML-G9-XXX
- Q.PEAK DUO BLK-G5/TS-XXX
- Q.PEAK DUO G6+/TS-XXX
- Q.PEAK DUO BLK-G6+/TS-XXX
- Q.PEAK DUO XL-G9.3-XXX
- Q.PEAK DUO-L-G8.2-XXX
- Q.PEAK DUO-L-G8.3-XXX
- Q.PEAK DUO-G5/SC-XXX
- Q.PEAK DUO-BLK-G5/SC-XXX
- Q.PEAK DUO-G6+/SC-XXX
- Q.PEAK DUO-BLK-G6+/SC-XXX
- Q.PEAK DUO-BLK-ML-G9-XXX
- Q.PEAK DUO-G5/TS-XXX
- Q.PEAK DUO-G6/TS-XXX
- Q.PEAK DUO BLK-G6/TS-XXX
- Q.PEAK DUO XL-G9.2-XXX
- Q.PEAK DUO BLK-G9-XXX
- Q.PEAK DUO ML-G9+-XXX
- Q.PEAK DUO BLK-G9+-XXX
- Q.PEAK DUO BLK ML-G9+-XXX
- Q.PEAK DUO XL-G10.2-XXX
- Q.PEAK DUO XL-G10.3-XXX
- Q.PEAK DUO XL-G10.d-XXX
- Q.PEAK DUO L-G8.3/BGT-XXX
- Q.PEAK DUO BLK ML-G10+-XXX
- Q.PEAK DUO BLK ML-G10-XXX
- Q.PEAK DUO BLK ML-G10.a+-XXX
- Q.PEAK DUO BLK ML-G10.a-XXX
- Q.PEAK DUO XL-G9.3/BFG-XXX
- Q.PEAK DUO XL-G10.3/BFG-XXX
- Q.PEAK DUO XL-G10.c-XXX
- Q.PEAK DUO L-G8.3/BFG-XXX
- Q.TRON\_XL-G2.3/BFG-XXX

Q.PEAK DUO ML-G10-XXX  
 Q.PEAK DUO ML-G10+-XXX  
 Q.PEAK DUO ML-G10.a+-XXX  
 Q.PEAK DUO ML-G10.a-XXX  
 Q.PEAK DUO BLK ML-G10.a+/TS-XXX,  
 Q.PEAK DUO G10-XXX,  
 Q.PEAK DUO BLK-G10-XXX,  
 Q.PEAK DUO G10+-XXX,  
 Q.PEAK DUO BLK-G10+-XXX  
 Q.TRON-G1+ XXX  
 Q.TRON BLK-G1+ XXX  
 Q.PEAK DUO BLK G10+/AC XXX  
 Q.PEAK DUO BLK G10+/HL XXX  
 Q.PEAK DUO XL-G11.3 XXX  
 Q.PEAK DUO XL-G11.3 BFG XXX  
 Q.Tron BLK M-G2+ XXX,  
 Q.Tron M-G2+ XXX,  
 Q.PEAK DUO BLK ML-G10+/t XXX  
 Q.PEAK DUO XL-G10.d/BFG  
 Q.TRON BLK M-G2+/AC XXX

HT-SAAE:  
 HT60-166M-XXX where XXX is 340-390;  
 HT60-182M-XXX

Hanwha Solar One:  
 HSL60P6-PB-2-XXXQ  
 HSL60P6-PB-4-XXXQ

Heliene:  
 60M-XXX  
 60P-XXX  
 72M-XXX  
 72P-XXX

Runergy:  
 \*\*HY-DH108N8  
 HY-DH108P8-XXX(Y)  
 \*\*HY-DH144N8  
 \*\*HY-DH144P8

Hyundai:  
 HiS-MXXXRG  
 HiS-SXXXRG  
 HiS-SXXXRW  
 HiA-SXXXMS  
 HiS-MXXXMG  
 HiS-SXXXMG  
 HiD-SXXXRG  
 HiS-SXXXXY  
 HiS-SXXXYI  
 HiS-SxxxYH  
 HiN-SxxxXG(BK)  
 All may be followed by (BK)

JA Solar:  
 JAM6-60-XXX/SI  
 JAP6-60-XXX/3BB  
 JAM60S09-XXX/PR  
 JAM60S10-XXX/MR  
 JAM60S10-XXX/PR  
 JAM60S12-XXX/PR

JAM60S17-XXX/MR  
JAP72S01-XXX/SC  
JAM72S09-XXX/PR  
JAM72S10-XXX/MR  
JAM72S10-XXX/PR  
JAM72S12-XXX/PR  
JAP6(k)-72-XXX/4BB  
JAM54S30-XXX/MR where XXX is 400-410,  
JAM54S31-XXX/MR  
JAM72D30-XXX/MB  
JAM72D10-XXX/MB

Jinko Solar:

JKMXXXM-60  
JKMXXXP-60  
JKMXXXP-60-J4  
JKMXXXP-60-V  
JKMXXXP-60B-J4  
JKMXXXPP-60  
JKMXXXPP-60-V  
JKMXXXM-60HL  
JKMXXXM-60L  
JKMXXXM-60HBL  
JKMXXXM-72  
JKMXXXP-72  
JKMXXXP-72-V  
JKMXXXPP-72  
JKMXXXPP-72-V  
JKMSXXXP-72  
JKMXXXM-72HL-V  
JKMXXXM-72HL-TV  
JKMXXXM-72L-V  
JKMXXXM-72HBL  
JKMXXXM-6TL3-B  
JKMXXXM-6RL3-B  
JKMXXXM-7RL3-V  
JKMXXXM-7RL3-TV  
JKMXXXM-72HL4-V  
JKMXXXM-72HL4-TV  
JKMXXXN-54HL4-B

KB Solar LLC:

MODULE-KBS-375-MONO  
MODULE-KBS-375-MONO-BF  
MODULE-KBS-450-MONO  
MODULE-KBS-450-MONO-BF

Kyocera:

KUXXX-6YYY  
KUXXX-8YYY

LG:

LGXXXN1C-A5  
LGXXXN1K-A5  
LGXXXQ1C-A5  
LGXXXQ1K-A5  
LGXXXS1C-A5  
LGXXXN2C-B3  
LGXXXN2W-B3  
LGXXXN1C-G4  
LGXXXN1K-G4

- LGXXS1C-G4
- LGXXN2C-G4
- LGXXN2K-G4
- LGXXN2W-G4
- LGXXS2C-G4
- LGXXS2W-G4
- LGXXN1C-V5
- LGXXN1W-V5
- LGXXN2T-V5
- LGXXN2T-J5
- LGXXN1T-V5
- LGXXA1C-V5
- LGXXM1C-L5
- LGXXN1C-N5
- LGXXM1K-L5
- LGXXN1K-L5
- LGXXN1C-A6
- LGXXQ1C-A6
- LGXXM1K-A6
- LGXXA1C-A6
- LGXXN1K-A6
- LGXXN1W-A6
- LGXXQ1K-A6
- LGXXM1C-A6
- LGXXQAK-A6
- LGXXN2W-E6
- LGXXN1K-E6
- LGXXQAC-A6
- LGXXN1K-B6
- LGXXN2T-E6
- LGXXN3K-V6

Longi:

- LR6-60-XXXM
- LR6-60BK-XXXM
- LR6-60HV-XXXM
- LR6-60PB-XXXM
- LR6-60PE-XXXM
- LR6-60PH-XXXM
- LR6-60HPB-XXXM
- LR6-60HPH-XXXM
- LR4-72HPH-XXXM
- LR4-60HIB-XXXM
- LR4-60HIH-XXXM
- LR4-60HPB-XXXM
- LR4-60HPH-XXXM
- LR6-60HIB-XXXM
- LR6-60HIH-XXXM
- LR5-54HPB-XXXM
- LR5-54HABB-XXXM

Maxon Solar Technologies, LTD.  
SPR-MAX3-XXX-BLK-R where xxx is 395-420

Meyer Burger:  
Meyer Burger Black \*\*  
Meyer Burger White \*\*

Mission Solar:  
MSEXXSO5T  
MSEXXSO5K  
MSEXXSQ5T

<p>TopRail Mounting System</p> <p>USL/CNL - Photovoltaic Mounting System: Model "TopRail" Mounting and Bonding Systems for use with Photovoltaic Modules, consisting of the following components: UR-40/45/60 Rail, Ultra Rail End Clamp, Ultra Rail Mid Clamp, RL RL Universal Link Assembly, Ground Lug, and MLPE Frame Attachment Kit.</p>	<p>Y</p>	<p>N</p>	<p>Y – Class A for Type 1, Type 2, and Type 29 modules.</p>	<p>MSEXXXSQ5K  MSEXXXMM4J  MSEXXXMM6J  MSEXXXSO6W  MSEXXXSO4J  MSEXXXSO6J  MSEXXXSQ6S  MSEXXXSQ4S  MSEXXXSR8K  MSEXXXSR8T  MSEXXXSR9S  MSE60AXXX  MSEXXXTS60  MSEXXXSX5K  MSEXXXSX5T  MSEXXXSX6S  MSEXXXSX6W  TXI6-XXX120BB  MSExxxSX5R, where xxx is 375 to 390  TXI10-XXX108BB  MSEXXXHT0B  where XXX is 390 to 410  MSEXXXSX9R  where XXX is 380 to 400</p> <p>Mitrex Inc:  Mxxx-I3H</p> <p>Next Energy Alliance:  USNEA-XXXM3-60  USNEA-XXXM3B-60  USNEA-XXXM3-72  USNEA-XXXM3B-72</p> <p>Panasonic:  VBHNXXXKA01  VBHNXXXKA02  VBHNXXXSA16  VBHNXXXKA03  VBHNXXXKA04  VBHNXXXSA17  VBHNXXXSA18  VBHNXXXSA17E  VBHXXXRA18N  VBHXXXRA03K  EVPVXXX(K)  EVPKXXXPK  EVPVXXXHK  EVPVXXXHK2 where XXX is 420 to 430</p> <p>Phono Solar:  PSXXXM-20/U  PSXXXMH-20/U  PSxxxM8GF-24/TH where xxx is 520 to 550,  PSxxxM8GFH-24/TH, where xxx is 520 to 550,  PSxxxM8GF-18/VH, where xxx is 390 to 410,  PSxxxM8GFH-18/VH, where xxx is 390 to 410,  PSxxxM6-24/TH, where xxx is 510 to 550.</p> <p>REC:</p>
---	----------	----------	---	--

RECXXXPE  
RECXXXPE-BLK  
RECXXXTP  
RECXXXTP-BLK  
RECXXXTP IQ  
RECXXXTP2  
RECXXXTP2-BLK  
RECXXXNP  
RECXXXTP2M  
RECXXXTP72  
RECXXXPE72  
RECXXXPE72XV  
RECXXXTP2M 72  
RECXXXTP2M 72 BLK  
RECXXXTP2M 72 BLK2  
RECXXXTP2SM 72  
RECXXXTP2SM 72 BLK  
RECXXXTP2SM 72 BLK2  
RECXXXAA  
RECXXXTP3  
RECXXXTP3M  
RECXXXTP4  
RECXXXAA Pure  
RECXXXNP2  
RECxxxAA PURE 2  
RECxxxAA PURE-RX

- All may be followed by BLK or BLACK

Renesola:

JCXXXM-24/Bb  
JCXXXM-24/BBh

SEG Solar:

SEG-XXX-BMB-HV,  
SEG-xxx-BMB-TB  
SEG-xxx-BMD-HV &  
SEG-xxx-BMD-TB,  
where xxx can be 370-425  
SEG-XXX-BTD-BG where xxx is 420-435

Silfab:

SLAXXX-M  
SLAXXX-P  
SSAXXX-M  
SSAXXX-P  
SLGXXX-M  
SLGXXX-P  
SSGXXX-M  
SSGXXX-P  
SILXXXBL  
SILXXXML  
SILXXXNT  
SILXXXHL  
SILXXXNL  
SILXXXBK  
SILXXXNX  
SILXXXNU  
SILXXXHC  
SILXXXHN  
SILXXXBG  
SILXXXQD

SILXXXQM  
SIL-xxxHC+,  
SIL-xxxHM.

S-Energy:  
SL65-54BGJ-XXXV  
SL65-54BHJ-XXXV  
SL65-54TEP-XXXV

Solaria:  
Solaria PowerXT-XXXR-PX  
Solaria PowerXT-XXXR-BX  
Solaria PowerXT-XXXR-AC  
Solaria PowerXT-XXXR-PM  
Solaria PowerXT-XXXR-PM-AC

SolarWorld:  
SWXXX-Mono  
SWXXX-Mono XL

SolarJuice (Solar4America)  
S4AXXX72H5BB,  
S4AXXX72H5BW,  
S4AXXX72M5BB,  
S4AXXX72M5BW,  
where XXX is 375-420.  
S4AXXX60M5BB,  
S4AXXX60M5BW,  
S4AXXX60H5BB,  
S4AXXX60H5BW,  
where XXX is 320-345  
S4AXXX-108MH10SB,  
S4AXXX-108MH10SW,  
S4AXXX-108MH10BB,  
S4AXXX-108MH10BW,  
Where XXX is 385-410.  
S4AXXX-108TH10BB,  
where XXX is 425 to 440.  
S4AXXX-144MH10STT,  
S4AXXX-144MH10BTT,  
where XXX is 530-565.  
S4AXXX-144TH10STT,  
S4AXXX-144TH16STT,  
where XXX is 565 to 590.

Suniva:  
MVX-XXX-60-5-701  
MVX-XXX-60-5-7B1  
OPT-XXX-60-4-100  
OPT-XXX-60-4-1B0  
OPT-XXX-60-4-800  
OPT-XXX-60-4-8B0

Sunpower:  
SPR-EYY-XXX  
SPR-EYY-XXX  
SPR-XYX-XXX  
SPR-XYX-XXX  
SPR-AXXX-G-AC  
SPR-AXXX  
SPR-AXXX-BLK-G-AC  
SPR-AXXX-BLK

SPR-MXXX-H-AC  
SPR-MXXX  
SPR-MXXX-BLK-H-AC  
SPR-MXXX-BLK

SunSpark:  
SST-XXXM3-60  
SST-XXXM3B-60  
SST-XXXM3-72  
SST-XXXM3B-72

Talesun:  
TP660M-XXX  
TP660P-XXX  
TP672M-XXX  
TP672P-XXX

Tesla:  
TXXXS  
TXXXH

Trina:  
TSM-XXXDD05(II)  
TSM-XXXDD05A.05(II)  
TSM-XXXDD05A.08(II)  
TSM-XXXDD05A.082(II)  
TSM-XXXPA05  
TSM-XXXPA05.05  
TSM-XXXPA05.08  
TSM-XXXPD05  
TSM-XXXPD05.002  
TSM-XXXPD05.05  
TSM-XXXPD05.05S  
TSM-XXXPD05.08  
TSM-XXXPD05.082  
TSM-XXXPD05.08D  
TSM-XXXPD05.08S  
TSM-XXXDD05H.05(II)  
TSM-XXXDD06M.05(II)  
TSM-XXXDE15H(II)  
TSM-XXXDE15M(II)  
TSM-XXXDE06X.05(II)  
TSM-XXXDE09.05  
TSM-XXXDE15V(II)  
TSM-XXXDE19  
TSM-XXXDEG15VC.20(II)  
TSM-XXXDEG18MC.20(II)  
TSM-XXXDEG19C.20  
TSM-XXXDEG21C.20  
TSM-XXXDE09C.05  
TSM-XXXDE09C.07

URECO  
FAMxxxE7G-BB  
FBMxxxMFG-BB

Vikram Solar:  
Somera VSMHBB.60.XXX.05  
SOMERA VSMH.72.XXX.05  
PREXOS VSMDHT.60.XXX.05  
PREXOS VSMDHT.72.XXX.05

VSUN Solar:  
VSUNXXX-144BMH-DG,  
VSUNXXX-120BMH,  
VSUNXXX-108BMH

Yingli:  
YLXXXA-29b  
YLXXXP-29b

ZNShine:  
ZXM6-60-XXX/M  
ZXM6-NH120-XXXM, ZXM6-NH144-XXXM  
ZXM7-SH108-XXX/M  
\*\*ZXM7-SHLDD144-XXX/M

REC Solar, model  
RECxxxAA Pure-R, where  
xxx can be 390-430

REC Solar, model  
RECxxxNP3, where xxx  
can be 380-410

Trina Solar, model  
TSM-xxxNE09RC.05,  
where xxx can be 365-430

Aptos Solar, model  
DNA-108-MF10-xxxW, where  
xxx can be 390-415

NRTL Listed Module Level Power  
Electronics:

Rapid Shutdown Devices:

AP Smart:  
Model RSD-S-PLC

Celestica International:  
DG-006-F001201x  
DG-006-F001401x

Delta Electronics:  
GPI00010105

Ginlong Technologies:  
Solis-RSD-1G  
Solis-MLRSD-R1-1G  
Solis-MLRSD-R2-1G

SMA:  
RSB-2S-US-10

Microinverters:

Enphase:  
M250  
M215  
C250  
IQ6-60-2-US  
IQ6PLUS-72-2-US

IQ7-60-2-US  
IQ7-60-B-US  
IQ7PLUS-72-2-US  
IQ7PLUS-72-B-US  
IQ8-60  
IQ8PLUS-72  
IQ8A-72  
IQ8H-208-72  
IQ8H-240-72

Optimizers:

Generac – Optimizer model S2502

Lunar Energy – Lunar Optimizer

SolarEdge:

P300-5NC4ARS  
P320-5NC4ARS  
P370-5NC4AFS  
P400-5NC4AFS  
P320  
P340  
P370  
P400  
P401  
P405  
P485  
P505  
P730  
P800p  
P850  
P860  
P950  
S440  
S500  
P1100  
P1101

Monitoring Devices:

Tigo:

TS4-R-F  
TS4-R-M  
TS4-R-O  
TS4-R-S  
TS4-R-M-DUO  
TS4-R-O-DUO  
TS4-R-S-DUO  
TS4-A-F  
TS4-A-2F  
TS4-A-O  
TS4-A-S

Philadelphia Solar:

\*\*PS-M144(HCBF)-XXXW  
PS-M108(HCBF)0XXXW

PS-M108(HC)-XXXW  
PS-M144(HC)-XXXW

Thornova:  
TS-BB54(XXX)  
TS-BB60(XXX)  
\*\*TS- BG54(XXX)  
TS-BG60(XXX)  
\*\*TS-BG72(XXX)

11/19/24, 4:30 PM

QIMS.E359313 - Mounting Systems, Mounting Devices, Clamping Devices and Ground Lugs for Use with Photovoltaic Modules a...

--	--	--	--	--

<p>RL Universal Mounting System</p> <p>USL - Mounting and Bonding Systems for use with Photovoltaic Modules, consisting of the following components: Mount Assembly, Ridge Mount Assembly, Umbrella Flashing Assembly, SpeedSeal Track Assembly, SpeedSeal Decktrack Assembly, Link Assembly, Wire Management Clips, Ground Lugs, MLPE Rail Attachment Kit and MLPE Frame Attachment Kit.</p>	<p>Y*</p>	<p>N</p>	<p>Y – Class A with and without skirt assembly for Type 1, Type 2 and Type 29 modules</p>	<p>Aptos Solar:                  DNA-120-MF23-XXX                  DNA-120-BF23-XXX                  DNA-144-MF23-XXX                  DNA-144-BF23-XXX                  DNA-120-MF26-XXXW, DNA-120-MF26-XXXW, DNA-144-MF26-XXXW                  DNA-120-BF26-XXXW                  DNA-144-BF26-XXXW                  DNA-120-BF10-xxx, where xxx is 435 to 455,                  DNA-108-BF10-xxx, where xxx is 385 to 410</p> <p>Boviet Solar:                  BVM7612M-XXX-H-HC-BF-DG</p> <p>Canadian Solar:                  CS6K-XXX-M                  CS6K-XXX-M-SD                  CS6K-XXX-P                  CS6K-XXX-P-SD                  CS6K-XXX-MS                  CS3K-XXX-P                  CS3W-XXX-P                  CS3N-XXX-MS                  CS3K-XXX-MS                  CS3U-XXX-MS                  CS3U-XXX-P                  CS1K-XXX-MS                  CS1H-XXX-MS                  CS1H-XXX-MS-AB                  CS1Y-XXX-MS                  CS6.1-54TM-XXXH                  CS3W-XXXMB-AG                  CS3Y-XXXMB-AG                  CS6W-XXXMB-AG                  CS6R-XXXMS-HL                  CS3W-xxxMS                  CS3W-xxxP, where xxx is 385 to 450</p> <p>CertainTeed                  CTXXXHC11-06,                  CTXXXHC11-06,                  CTXXXHC11-06</p> <p>Chint Solar:                  CHSM6612M-XXX                  CHSM6612M/HV-XXX                  CHSM6612M(BL)-XXX                  **CHSM72M-HC-XXX (Astro 4)                  **CHSM72M-HC-XXX (Astro 5)</p> <p>Crossroads Solar:                  Crossroads Solar xxx</p> <p>Dehui Solar:                  DH-M760B-XXXW                  DH-M760W-XXXW                  DH-M772W-XXXW                  DH-M760F-XXXW                  DH-M772F-XXXW</p>
---	-----------	----------	---	---

Freedom Forever Procurement:  
FF-MP-BBB-xxx, where xxx is 365 to 410.

Hansol Technics  
HAXXXAA-NNEA0  
where XXX is 420 to 440

Hanwha/Q Cells:  
Q.PEAK DUO-G5-XXX  
Q.PEAK DUO-BLK-G5-XXX  
Q.PLUS DUO-G5-XXX  
Q.PEAK DUO-G7-XXX  
Q.PEAK DUO-BLK-G7-XXX  
Q.PEAK DUO-G7.2-XXX  
Q.PEAK DUO-G6+-XXX  
Q.PEAK DUO-BLK-G6+-XXX  
Q.PEAK DUO-G6-XXX  
Q.PEAK DUO-XL-G9.3-XXX  
Q.PEAK DUO-BLK-G6-XXX  
Q.PEAK DUO-G8+-XXX  
Q.PEAK DUO-BLK-G8+-XXX  
Q.PEAK DUO-G8-XXX  
Q.PEAK DUO-BLK-G8-XXX  
Q.PEAK DUO BLK-G6+/AC-XXX  
Q.PEAK DUO-ML-G9-XXX  
Q.PEAK DUO-BLK-ML-G9-XXX 365-385  
Q.PEAK DUO XL-G9.2-XXX  
Q.PEAK DUO BLK-G9-XXX  
Q.PEAK DUO ML-G9+-XXX  
Q.PEAK DUO BLK-G9+-XXX  
Q.PEAK DUO BLK ML-G9+-XXX  
Q.PEAK DUO XL-G10.2-XXX  
Q.PEAK DUO XL-G10.3-XXX  
Q.PEAK DUO XL-G10.d-XXX  
Q.PEAK DUO L-G8.3/BGT-XXX  
Q.PEAK DUO BLK ML-G10+-XXX  
Q.PEAK DUO BLK ML-G10-XXX  
Q.PEAK DUO BLK ML-G10.a+-XXX  
Q.PEAK DUO BLK ML-G10.a-XXX  
Q.PEAK DUO XL-G9.3/BFG-XXX  
Q.PEAK DUO XL-G10.3/BFG-XXX  
Q.PEAK DUO XL-G10.c-XXX  
Q.PEAK DUO L-G8.3/BFG-XXX  
Q.TRON\_XL-G2.3/BFG-XXX  
Q.PEAK DUO ML-G10-XXX  
Q.PEAK DUO ML-G10+-XXX  
Q.PEAK DUO ML-G10.a+-XXX  
Q.PEAK DUO ML-G10.a-XXX,  
Q.PEAK DUO G10-XXX,  
Q.PEAK DUO BLK-G10-XXX,  
Q.PEAK DUO G10+-XXX,  
Q.PEAK DUO BLK-G10+-XXX  
Q.TRON-G1+ XXX  
Q.TRON BLK-G1+ XXX  
Q.PEAK DUO BLK G10+/AC XXX  
Q.PEAK DUO BLK G10+/HL XXX  
Q.PEAK DUO XL-G11.3 XXX  
Q.PEAK DUO XL-G11.3 BFG XXX  
Q.Tron BLK M-G2+ XXX,  
Q.Tron M-G2+ XXX,  
Q.PEAK DUO BLK ML-G10+/t XXX  
Q.PEAK DUO XL-G10.d/BFG

Q .TRON BLK M-G2+/AC XXX

HT-SAAE:

HT60-166M-XXX where XXX is 340-390;  
HT60-182M-XXX

Heliene:

60M-XXX  
60P-XXX  
72M-XXX  
72P-XXX

Runergy:

HY-DH108N8-XXX  
HY-DH108P8-XXX(Y)  
HY-DH144N8-XXX  
HY-DH144P8-XXX

Hyundai:

HiA-SXXXMS  
HiS-SXXXXY  
HiS-SXXXXI  
HiS-SxxxYH  
HiN-SxxxXG(BK)

All may be followed by (BK)

JA Solar:

JAM60S09-XXX/PR  
JAM72S09-XXX/PR  
JAM60S10-XXX/MR  
JAM72S10-XXX/MR  
JAM60S10-XXX/PR  
JAM72S10-XXX/PR  
JAM60S12-XXX/PR  
JAM72S12-XXX/PR  
JAM60S17-XXX/MR  
JAM54S30-XXX/MR where XXX is 400-410,  
JAM54S31-XXX/MR  
JAM72D30-XXX/MB  
JAM72D10-XXX/MB

Jinko Solar:

JKMXXXM-60  
JKMXXXP-60  
JKMXXXP-60-J4  
JKMXXXP-60-V  
JKMXXXP-60B-J4  
JKMXXXPP-60  
JKMXXXPP-60-V  
JKMXXXM-60HL  
JKMXXXM-60L  
JKMXXXM-60HBL  
JKMXXXM-72  
JKMXXXP-72  
JKMXXXP-72-V  
JKMXXXPP-72  
JKMXXXPP-72-V  
JKMSXXXP-72  
JKMXXXM-72HL-V  
JKMXXXM-72HL-TV  
JKMXXXM-72L-V

JKMXXXM-72HBL  
JKMXXXM-6TL3-B  
JKMXXXM-6RL3-B  
JKMXXXM-7RL3-V  
JKMXXXM-7RL3-TV  
JKMXXXM-72HL4-V  
JKMXXXM-72HL4-TV  
JKMXXXN-54HL4-B

KB Solar LLC:  
MODULE-KBS-375-MONO  
MODULE-KBS-375-MONO-BF  
MODULE-KBS-450-MONO  
MODULE-KBS-450-MONO-BF

LG:  
LGXXXN1C-A5  
LGXXXN1K-A5  
LGXXXQ1C-A5  
LGXXXQ1K-A5  
LGXXXS1C-A5  
LGXXXN2C-B3  
LGXXXN2W-B3  
LGXXXN1C-G4  
LGXXXN1K-G4  
LGXXXS1C-G4  
LGXXXN2C-G4  
LGXXXN2K-G4  
LGXXXN2W-G4  
LGXXXS2C-G4  
LGXXXS2W-G4  
LGXXXN1C-V5  
LGXXXN1W-V5  
LGXXXN2T-V5  
LGXXXN2T-J5  
LGXXXN1T-V5  
LGXXXA1C-V5  
LGXXXM1C-L5  
LGXXXN1C-N5  
LGXXXN1C-A6  
LGXXXQ1C-A6  
LGXXXM1K-A6  
LGXXXA1C-A6  
LGXXXN1K-A6  
LGXXXN1W-A6  
LGXXXQ1K-A6  
LGXXXM1C-A6  
LGXXXQAK-A6  
LGXXXN2W-E6  
LGXXXN1K-E6  
LGXXXQAC-A6  
LGXXXN1K-B6  
LGXXXN2T-E6  
LGXXXN3K-V6

Longi:  
LR6-60-XXXM  
LR6-60BK-XXXM  
LR6-60HV-XXXM  
LR6-60PB-XXXM  
LR6-60PE-XXXM  
LR6-60PH-XXXM

LR6-60HPB-XXXM  
LR6-60HPH-XXXM  
LR4-72HPH-XXXM  
LR4-60HIB-XXXM  
LR4-60HIH-XXXM  
LR6-60HIB-XXXM  
LR4-60HPB-XXXM  
LR4-60HPH-XXXM  
LR6-60HIH-XXXM  
LR5-54HPB-XXXM  
LR5-54HABB-XXXM

Maxeon Solar Technologies, LTD.  
SPR-MAX3-XXX-BLK-R where xxx is 395-420

Meyer Burger:  
\*\*Meyer Burger Black  
\*\*Meyer Burger White

Mission Solar:  
MSEXXXSO5T  
MSEXXXSO5K  
MSEXXXSQ5T  
MSEXXXSQ5K  
MSEXXXMM4J  
MSEXXXMM6J  
MSEXXXSO6W  
MSEXXXSO4J  
MSEXXXSO6J  
MSEXXXSQ6S  
MSEXXXSQ4S  
MSEXXXSR8K  
MSEXXXSR8T  
MSEXXXSR9S  
MSE60AXXX  
MSEXXXSX5T MSEXXXSX5K  
MSEXXXSX6W  
MSEXXXSX6S  
TXI6-XXX120BB  
MSExxxSX5R, where xxx is 375 to 390  
TXI10-XXX108BB  
MSEXXXHT0B  
where XXX is 390 to 410  
MSEXXXSX9R  
where XXX is 380 to 400

Mitrex Inc:  
Mxxx-13H

Next Energy Alliance:  
USNEA-XXXM3-60  
USNEA-XXXM3B-60  
USNEA-XXXM3-72  
USNEA-XXXM3B-72

Panasonic:  
VBHNXXXKA03  
VBHNXXXKA04  
VBHNXXXSA17  
VBHNXXXSA18  
VBHNXXXSA17E

				<p>VBHXXXRA18N                  VBHXXXRA03K                  EVPVXXX(K)                  EVPVXXXH                  EVPVXXXPK                  EVPVXXXHK                  EVPVXXXHK2 where XXX is 420 to 430</p> <p>Phono Solar:                  PSXXXM-20/U                  PSXXXMH-20/U                  PSxxxM8GF-24/TH where xxx is 520 to 550,                  PSxxxM8GFH-24/TH, where xxx is 520 to 550,                  PSxxxM8GF-18/VH, where xxx is 390 to 410,                  PSxxxM8GFH-18/VH, where xxx is 390 to 410,                  PSxxxM6-24/TH, where xxx is 510 to 550.</p> <p>REC:                  RECXXTP2                  RECXXTP2-BLK                  RECXXTP2M                  RECXXTP2M 72                  RECXXTP2M 72 BLK                  RECXXTP2M 72 BLK2                  RECXXTP2SM 72                  RECXXTP2SM 72 BLK                  RECXXTP2SM 72 BLK2                  RECXXXAA                  RECXXTP3M                  RECXXNP                  RECXXTP4                  RECXXXAA Pure                  RECXXNP2                  RECxxxAA PURE 2                  RECxxxAA PURE-RX                  - All may be followed by BLK or BLACK</p> <p>SEG Solar:                  SEG-XXX-BMB-HV,                  SEG-xxx-BMB-TB</p>
--	--	--	--	--

SEG-xxx-BMD-HV &  
 SEG-xxx-BMD-TB, where  
 xxx can be 370-425 SEG-XXX-BTD-BG  
 where xxx is 420-435

Silfab:  
 SLAXXX-M  
 SLAXXX-P  
 SSAXXX-M  
 SSAXXX-P  
 SLGXXX-M  
 SLGXXX-P  
 SSGXXX-M  
 SSGXXX-P  
 SILXXXBL  
 SILXXXML  
 SILXXXNT  
 SILXXXHL  
 SILXXXNL

<p>TopSpeed Mounting System</p> <p>USL - Mounting and Bonding Systems for use with Photovoltaic Modules, consisting of the following components: Mount, Row Link, Skirt Assembly, Wire Management Clips, Ground Lugs, MLPE Frame Attachment Kit.</p>	<p>Y*</p>	<p>N</p>	<p>Y – Class A with and without skirt assembly for Type 1, Type 2 and Type 29 modules</p>	<p>SILXXXBK                  SILXXXNX                  SILXXXNU                  SILXXXHC                  SILXXXHN                  SILXXXBG                  SILXXXQD                  SILXXXQM                  SIL-xxxHC+                  SIL-xxxHM</p> <p>S-Energy:                  SL65-54BGJ-XXXV                  SL65-54BHJ-XXXV</p> <p>Solaria:                  Solaria PowerXT-XXXR-PX                  Solaria PowerXT-XXXR-BX                  Solaria PowerXT-XXXR-AC                  Solaria PowerXT-XXXR-PM                  Solaria PowerXT-XXXR-PM-AC</p> <p>SolarJuice (Solar4America)                  S4AXXX72H5BB,                  S4AXXX72H5BW,                  S4AXXX72M5BB,                  S4AXXX72M5BW,                  where XXX is 375-420.                  S4AXXX60M5BB,                  S4AXXX60M5BW,                  S4AXXX60H5BB,                  S4AXXX60H5BW,                  where XXX is 320-345                  S4AXXX-108MH10SB,                  S4AXXX-108MH10SW,                  S4AXXX-108MH10BB,                  S4AXXX-108MH10BW,                  Where XXX is 385-410.                  S4AXXX-108TH10BB,                  where XXX is 425 to 440.                  S4AXXX-144MH10STT,                  S4AXXX-144MH10BTT,                  where XXX is 530-565                  S4AXXX-144TH10STT,                  S4AXXX-144TH16STT,                  where XXX is 565 to 590.</p> <p>SunPower:                  SPR-AXXX-G-AC                  SPR-AXXX                  SPR-AXXX-BLK-G-AC                  SPR-AXXX-BLK                  SPR-MXXX-H-AC                  SPR-MXXX                  SPR-MXXX-BLK-H-AC                  SPR-MXXX-BLK</p> <p>SunSpark:                  SST-XXXM3-60                  SST-XXXM3B-60                  SST-XXXM3-72                  SST-XXXM3B-72</p>
--	-----------	----------	---	--

## Talesun:

TP660M-XXX  
TP660P-XXX  
TP672M-XXX  
TP672P-XXX

## Trina:

TSM-XXXDD05(II)  
TSM-XXXDD05A.05(II)  
TSM-XXXDD05A.08(II)  
TSM-XXXDD05A.082(II)  
TSM-XXXPA05  
TSM-XXXPA05.05  
TSM-XXXPA05.08  
TSM-XXXPD05  
TSM-XXXPD05.002  
TSM-XXXPD05.05  
TSM-XXXPD05.05S  
TSM-XXXPD05.08  
TSM-XXXPD05.082  
TSM-XXXPD05.08D  
TSM-XXXPD05.08S  
TSM-XXXDD05H.05(II)  
TSM-XXXDD06M.05(II)  
TSM-XXXDE15H(II)  
TSM-XXXDE15M(II)  
TSM-XXXDE06X.05(II)  
TSM-XXXDE09.05  
TSM-XXXDE15V(II)  
TSM-XXXDE19  
TSM-XXXDEG15VC.20(II)  
TSM-XXXDEG18MC.20(II)  
TSM-XXXDEG19C.20  
TSM-XXXDEG21C.20  
TSM-XXXDE09C.05  
TSM-XXXDE09C.07

## URECO

FAMxxxE7G-BB  
FBMxxxMFG-BB

## Vikram Solar:

SOMERA VSMHBB.60.XXX.05  
SOMERA VSMH.72.XXX.05  
PREXOS VSMDHT.60.XXX.05  
PREXOS VSMDHT.72.XXX.05

## VSUN Solar:

VSUNXXX-144BMH-DG,  
VSUNXXX-120BMH,  
VSUNXXX-108BMH

## ZNShine:

ZXM6-60-XXX/M  
ZXM6-NH120-XXXM, ZXM6-NH144-XXXM,  
ZXM7-SH108-XXX/M  
\*\*ZXM7-SHLDD144-XXXM

REC Solar, model  
RECxxxAA Pure-R,

where xxx can be 390-430

REC Solar, model  
RECxxxNP3, where  
xxx can be 380-410

Trina Solar, model  
TSM-xxxNE09RC.05, where  
xxx can be 365-430

Aptos Solar, model  
DNA-108-MF10-xxxW, where  
xxx can be 390-415

NRTL Listed Module Level Power  
Electronics:

Rapid Shutdown Devices:

AP Smart:  
Model RSD-S-PLC

Celestica International:  
DG-006-F001201x  
DG-006-F001401x

Delta Electronics:  
GPI00010105

Ginlong Technologies:  
Solis-RSD-1G  
Solis-MLRSD-R1-1G  
Solis-MLRSD-R2-1G

SMA:  
RSB-2S-US-10

Microinverters:

Enphase:  
M250  
M215  
C250  
IQ6-60-2-US  
IQ6PLUS-72-2-US  
IQ7-60-2-US  
IQ7-60-B-US  
IQ7PLUS-72-2-US  
IQ7PLUS-72-B-US  
IQ8-60  
IQ8PLUS-72  
IQ8A-72  
IQ8H-208-72  
IQ8H-240-72

Optimizers:

Lunar Energy – Lunar Optimizer

SolarEdge:  
P300-5NC4ARS  
P320-5NC4ARS

P370-5NC4AFS  
P400-5NC4AFS  
P320  
P340  
P370  
P400  
P401  
P405  
P485  
P505  
P730  
P800p  
P850  
P860  
P950  
S440  
S500  
P1100  
P1101

Monitoring Devices:

Tigo:  
TS4-R-F  
TS4-R-M  
TS4-R-O  
TS4-R-S  
TS4-R-M-DUO  
TS4-R-O-DUO  
TS4-R-S-DUO  
TS4-A-F  
TS4-A-2F  
TS4-A-O  
TS4-A-S

Generac – Optimizer model S2502

Philadelphia Solar:  
\*\*PS-M144(HCBF)-XXXW  
PS-M108(HCBF)0XXXW

PS-M108(HC)-XXXW  
PS-M144(HC)-XXXW

:

Thornova:  
TS-BB54(XXX)  
TS-BB60(XXX)  
\*\*TS- BG54(XXX)  
TS-BG60(XXX)  
\*\*TS-BG72(XXX)

--	--	--	--

**Photovoltaic Ground Lug - Bolt-through Design - Tested in Combina**

Cat. No.	Max OCPD (A)	Standard Mounting Hardware Provided	Investigated for Bonding	Mounting	Min Profile (w x l)	Mounting Surface			Mounting Screw Size	Tightening Torque (lbs-in.)	Mounting-hole Range		Wire Type (Mtl)	Field-wir Typ
						Min Thk	Max Thk	Mtl			Min	Max		
242-02101	20	Y	Y	N	1.5 in. x 1.5 in.	Mounted on Snaprack Ground or Standard Rails	AL	Anodized	5/16-18	16	N/A	N/A	CU	Soli
242-92202	20	Y	Y	N	0.5 in. x 0.5 in	Mounted on RL Leverlock Slider Assembly Rails	AL	Anodized	5/16-18	8 ft-lb	N/A	N/A	CU	Soli

**Photovoltaic Bonding Device: MLPE Frame Attachment Kit**

Cat. No.	Max OCPD (A)	Frame Thickness Anodized AL (mm)	MLPE Thickness AL(mm)	MLPE Thickness SS 304 (mm)	MLPE Slot Width (mm)	Torque Value	Tested in Combination With:
242-02151	20	0.8 - 2.4	2.0 - 3.2	2.0	8.1 - 8.5	10 ft.lb.	PV Modules Described in Mounting Systems noted above with frame thickness limitations.

The following components have been tested for roof penetration utilizing the Wind-Driven Rain Test from UL Subject 2582:

Cat. No.	Tested with the Following Securement Means	Tested with the Following Seal/Sealant & Specific Location	Tested with the Following Roof Deck Construction
<b>Photovoltaic mounting system component</b>			
RL Universal Mounting System - Umbrella Bolt Flashing consisting of Composition flashing, Flash Track PRC, Flash Track End Caps, Umbrella Bolt; SpeedSeal Track.	Lag Bolt	No sealant	Asphalt shingles
UR-40 Mounting System - Consisting of the following components: Composition flashing, Umbrella L-foot, Umbrella Bolt; SpeedSeal Foot Assembly kit	Lag Bolt	No sealant	Asphalt shingles
UR-60 Mounting System - Consisting of the following components: Composition flashing, Umbrella L-foot, Umbrella Bolt, and SpeedSeal Foot Assembly kit	Lag Bolt	No sealant	Asphalt shingles


\* - Not all components have been evaluated for bonding. See UL report and instruction manual for details.

\*\* - Modules with this mark do not have the correct fire typing to meet system fire classification requirements.

Trademark and/or Tradename: "SNAPNRACK"

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."



# SnapNrack™

Solar Mounting Solutions

---

## TopSpeed™ Mounting System

Installation Manual

---

[snapnrack.com](https://snapnrack.com)

SnapNrack's primary goal is to provide our customers with the lowest possible installed cost for mounting residential solar modules, without compromising the values the industry has come to expect: ease of use, quality, aesthetics, and safety. Designing with this goal in mind, we are proud to present the SnapNrack TopSpeed™ mounting system with SpeedSeal™ Technology.

SnapNrack has created a ground breaking system combining great features and benefits we are known for, with our TopSpeed™ System and the most up to date technical innovation in the industry, thus reducing parts while driving down labor, material, and total installation costs. Designed to work with standard module frames, achieving UL 2703 Listing for Grounding/Bonding and Fire Classification, providing integrated wire management, aesthetics and our industry leading "Snap-In" features, SnapNrack is providing the simplest and most cost effective solar mounting solution on the market with TopSpeed™ including integrated fasteners and SpeedSeal™ Technology.

### Advantages of Installing the SnapNrack TopSpeed™ System

**Modules are installed with a minimum number of parts**

This elimination of parts leads to a lower estimated system cost for both the installer and home owner.

**Built in Wire Management and Aesthetics**

Extensive wire management solutions have been designed specifically for the system that adapts to multiple possible mounting positions.

The system is designed to be aesthetically pleasing and sturdy with a skirt that provides considerable strength at the leading edge and an elegant look for those seeking high end looking systems.

**SnapNrack TopSpeed™ includes SpeedSeal™ Technology**

SpeedSeal™ Technology features integrated flashing. This eliminates loosening layers of composition and removing nails with a pry bar, leading to less damage to the roof, minimized potential roof leaks, and much faster installs.

**TopSpeed™ Mounts attach Directly to the Decking**

As well as all of the benefits associated with the standard SpeedSeal™ Technology, TopSpeed™ attaches to the roof sheathing and does not require rafter attachment. Simply attaching to the roof sheathing removes the requirement for finding rafters and drilling pilot holes, creating potential rafter misses that can cause leaks.

# Table of Contents

## Project Plans

Certification Details . . . . .	4
Component Details . . . . .	5
Pre-Installation Requirements . . . . .	7

## Installation Steps

TopSpeed™ Skirt Layout . . . . .	8
TopSpeed™ Mount to Module Installation . . . . .	9
TopSpeed™ Mount Skirt Installation . . . . .	10
Wire Management . . . . .	13
MLPE Attachment . . . . .	16
Module Installation . . . . .	19

## Grounding Specifications . . . . . 22

Maintaining the Grounding Bonding When Removing a Module . . . . .	23
Appendix A: List of approved Modules and MLPEs . . . . .	25

## Certification Details

---

SnapNrack TopSpeed™ mounting system has been evaluated by Underwriters Laboratories (UL) and Listed to UL Standard 2703 for Grounding/Bonding, and Fire Classification.

### **Grounding/Bonding**

Only specific components have been evaluated for bonding, and are identified as being in the ground path. The TopSpeed™ components that have been evaluated for bonding are the Mount Assembly (Mount Clamp Top, Module Clamp Tower, Angle Bracket), Clamp Assembly, Universal Skirt, Universal Skirt Clamp, Ground Lugs, and Smart Clips.

Universal Skirt Spacers, Mount Channel Nut, and Mount Base are not required to be bonded to the system based on the exceptions in clause 9.1 of UL 2703 1st Ed. Wire management clips are utilized to route conductors away from these components and must be assembled according to the instructions.

This mounting system may be used to ground and/or mount a PV module complying with UL 1703 or UL 61703 only when the specific module has been evaluated for grounding and/or mounting in compliance with the included instructions. See Appendix A for the list of modules tested for use with the TopSpeed™ System for integrated grounding.

Ground Lugs have been evaluated to both UL 467 and UL 2703 Listing requirements. The following ground lugs have been approved for use: SnapNrack model 242-92202, and IlSCO models GBL-4DBT and SGB-4.

The following components have been evaluated for bonding as the fault current ground path: TopSpeed™ Mount Assembly, (Mount Clamp Top, Module Clamp Tower, Angle Bracket), Clamp Assembly, Wire Management Clips, and Ground Lugs. In order to maintain the Listing for bonding, wire management clips must be assembled to route conductors away from parts that have not been evaluated for bonding.

A Listed (QIMS) and Unlisted Component (KDER3) grounding lug, SnapNrack part no. 242-92202, is attached to the module frame flange for the normal attachment of a Grounding Electrode Conductor, which provides bonding within the system and eventual connection to a Grounding Electrode, as required by the U.S. NEC. Details of part no. 242-92202 can be found in Volume 1, Section 4, and Volume 2, Section 2. When this method is used, the grounding symbol is stamped onto the body of the ground lug to identify the grounding terminal.

An alternate method of grounding, a UL Listed (KDER and QIMS) grounding lug, IlSCO (E34440 and E354420) model SGB-4 is attached to the module frame flange. When this method is used, the grounding terminal is identified by the green colored screws of the lug.

An alternate method of grounding, a UL Listed (KDER and QIMS) grounding lug, IlSCO (E34440 and E354420) model GBL-4BDT is attached to the module frame flange through the specified hardware and torque values. When this method is used, the grounding terminal is identified by the green colored set screw of the lug.

An alternate method of grounding, Enphase R/C (QIKH2)(QIMS2) model M250, M215 & C250 is bonded to the Listed PV module frame by the Enphase R/C (QIMS2) Model EFM-XXMM anodization piercing mounting/clamping kit. The total roof-mounted PV system is bonded (modules and microinverters) together and the assembly is bonded to ground through the Enphase R/C (QIMS2) Engage Cables; Model ETXX-240, ETXX-208 or ETXX-277, when properly grounded at the service entrance. R/C (QIMS2), Dynoraxx (E357716) photovoltaic bonding device cat. no. Dynobond is an optional component that may be used with this system. The Dynobond device has been evaluated to provide module to module bonding. The Dynobond device attaches to the frame flange of adjacent modules Listed (QIMS), SnapNrack MLPE Frame Attachment Kit model 242-02151 has been investigated to bond approved MLPE device back plates to frames of modules.

## **Fire**

SnapNrack TopSpeed™ has been investigated for a Class A System Fire Classification for Steep-Sloped and low sloped roofs with Type 1 and Type 2 modules. Because the system was tested at 5 inches above the test roof fixture, TopSpeed™ can be installed without any height restrictions due to System Fire Classification. See Appendix A for potential module-specific height restrictions due to module temperature. The Skirt is considered an optional component with respect to Fire Classification, as SnapNrack TopSpeed™ maintains the same Fire Classification Rating both with and without the skirt.

**NOTE:** Modules with an asterisk\* have a fire rating that is different from Type 1, Type 2 or Type 29. SNR systems have only been evaluated for use with Type 1, Type 2, or Type 29 modules. Modules with a different fire type rating should be considered to not have been evaluated for use with SNR systems with respect to a system fire rating.

## **Inspection Practices**

SnapNrack recommends a periodic re-inspection of the completed installation for loose components, loose fasteners, and any corrosion, such that if found, the affected components are to be immediately replaced.

# Component Details


snapnrack.com

## TopSpeed™ Structural Components



### TopSpeed™ Mount

SnapNrack TopSpeed™ Mount assembly including SpeedSeal™ base, clamp top, and (4) SnapNrack #14 SS Wood Screws with 1/2" Hex Head.



### TopSpeed™ Clamp


SnapNrack TopSpeed™ Clamp assembly including including Link bottom, Link top, and springs.



### Universal Skirt


SnapNrack Universal Skirt in double portrait or single landscape lengths.

## Wire Managements Components




### Skirt Spacers

SnapNrack Universal Skirt Spacer for 40mm, 38mm, 35mm, 32mm, and 30mm modules.



### Smart Clip


Module frame cable clip, holds two PV wires or Enphase IQ-Cables.



### Smart Clip XL


Module frame cable clip, holds six PV wires or four Enphase IQ-Cable.

## Grounding/MLPE Components




### Wire Saver

Designed to secure conductors that become loose and hang below the array, holds one conductor.



### Ground Lug

SnapNrack Ground Lug assembly used for attaching the Equipment Grounding Conductor on to one module or any TopSpeed™ Mount per array. 5



### MLPE Frame Attachment Kit

Attaches MLPEs (Module Level Performance Enhancers) and other related equipment to the module frame.

## Hardware Torque Specifications

The recommended torque to be applied to components for proper assembly and bonding are as follows:

Hardware Description	Torque Specification
All TopSpeed™ ½” bolts; System Leveling Bolt, TopSpeed™ Mount Clamping Bolt, Clamp Bolt	16 ft-lb
Ground Lug model 242-92202 to Module Frame or anywhere on the TopSpeed™ Mount, and Ground Lug model 242-92202 to Grounding Electrode Conductor (6-12 SOL)	8 ft-lb
MLPE Frame Attachment Kit, MLPE Rail Attachment Kit	10 ft-lb
SolarEdge Frame Mounted Microinverter Bracket to Module Frame	11 ft-lb
Enphase Frame Mounted Microinverter Bracket to Module Frame	13 ft-lb
Ground Lug model SGB-4 to module	75 in-lb
Ground Lug model SGB-4 to Grounding Electrode Conductor (4-14 SOL or STR)	35 in-lb
Ground Lug model GBL-4DBT to module	35 in-lb
Ground Lug model GBL-4DBT to Grounding Electrode Conductor (10-14 SOL or STR)	20 in-lb
Ground Lug model GBL-4DBT to Grounding Electrode Conductor (8 SOL or STR)	25 in-lb
Ground Lug model GBL-4DBT to Grounding Electrode Conductor (4-6 SOL or STR)	35 in-lb

# Pre-Installation Requirements

snapnrack.com

## Site Survey

- Measure the roof surfaces and develop an accurate drawing, including any obstacles such as chimneys and roof vents.
- If plans for the roof structure are available, verify that the plans match the final structure.
- Identify any roof access or setback areas as required by the local AHJ.
- Identify any construction issues that may complicate the process of locating rafters from the roof surface.
- If you find structural problems such as termite damage or cracked rafters that may compromise the structure's integrity consult a structural engineer.

## Design Guidance

- PV Designers should account for the 0.75 inch spacing between rows and columns of modules when creating the layout.
- Determine site conditions for calculating the engineering values, confirm site conditions and code versions comply with local AHJ requirements.
- Reference site conditions and system specifications in TopSpeed™ Structural Engineering Report to determine the number of attachments per module side.
- Insert SnapNrack installation details into design plan set specific to the project requirements.
- Draw roof attachment locations on plan set layout based on TopSpeed™ Structural Engineering.

### Best Practice:

If environmental load conditions require three TopSpeed™ attachments per module side this is only required when modules share attachments.

- Identify homerun and Junction Box locations based on rooftop wiring requirements.
- Mark distance from array edge to identifiable roof feature in x and y axes.

### Safety Guidance

- Always wear appropriate OSHA approved safety equipment when at active construction site.
- Appropriate fall protection or prevention gear should be used. Always use extreme caution when near the edge of a roof.
- Use appropriate ladder safety equipment when accessing the roof from ground level.




Image note: X-Axis described in this manual is cross-slope on the roof, Y-Axis is in line with the roof slope.





Image note: This four module array is installed in a high load configuration with three attachments per side where two modules share attachments. See highlighted area. As shown, three attachments are never required at the skirt or the top of the array.

### Safety Guidance Continued

- Safety equipment should be checked periodically for wear and quality issues.
- Always wear proper eye protection when required.

# TopSpeed™ Mount to Module Frame Installation

snapnrack.com

## Required Tools

● Socket Wrench/Impact Driver

● Torque Wrench


● 1/2" Socket

## Materials Included - TopSpeed™ System with SpeedSeal™ Technology


- 1 (1) SnapNrack TopSpeed™ Mount
- 2 (4) SnapNrack #14 Wood Screw with 1/2" Hex Head & sealing washer

### Best Practice:


Attach all TopSpeed™ mounts as the modules are being prepped with MLPEs on the ground. Attach Mounts before attaching MLPEs to simplify wire management.




## INSTALLATION INSTRUCTIONS



1) Assemble all TopSpeed™ Mounts required for the installation. Slide the clamp tower assembly into the angle bracket riser and tighten the leveling bolt to 16 ft-lbs.



2) Position TopSpeed™ Mount clamp on the module frame within the module manufacturers required clamping zone.



3) Tighten 1/2" clamping bolt to 16 ft-lb. Only two Mounts are required per module on one side.

### Install Note:

For high load conditions add a third attachment in the middle of the module frame.

# TopSpeed™ Universal Skirt Layout

snapnrack.com

## Required Tools

- Roof Marking Crayon or Chalk
- Tape Measure


## LAYOUT INSTRUCTIONS

1) Use a tape measure to verify that all modules will fit properly on the roof surface.

2) On the roof draw the layout for the skirt installation including module gaps (recommended 0.75 inch gap), bottom corners, and locations of the two TopSpeed™ attachments per module that clamp to the skirt. Three attachments per module is never required at the skirt.

### Install Note:

If environmental load conditions require three TopSpeed™ attachments per module side this is only required when modules share attachments.



# TopSpeed™ Mount: Skirt Installation


snaprack.com

## Required Tools

- Socket Wrench/Impact Driver
- Torque Wrench
- 1/2" Socket
- Roofing sealant

## Materials Included - TopSpeed™ Mount with SpeedSeal™ Technology


- ① (1) TopSpeed™ Mount
- ② (1) TopSpeed™ Clamp
- ③ (1) Universal Skirt
- ④ (1) Universal Skirt Spacers
- ⑤ (1) *OPTIONAL* - Universal Link




# TopSpeed™ Mount Skirt Installation

snapnrack.com


## INSTALLATION INSTRUCTIONS



1) Install TopSpeed™ Mounts at locations drawn during the skirt layout. Mounts must be installed entirely on one course of composition.




2) Fill both cavities on bottom of TopSpeed™ Mount created by SpeedSeal™ gasket with roof sealant to ensure a watertight seal.




3) Attach TopSpeed™ Mount to roof using the (4) SnapNrack #14 Wood Screws with 1/2" hex head that are captured in the Mount.

### Install Note:


Roof sealant should be expelled from both vents of the TopSpeed™ Mount as it is installed to assure the proper amount of roof sealant has been applied. If sealant is not expelled from all four vents, remove TopSpeed™ Mount, add more sealant to the cavity, then reinstall.



4) Loosen Course Adjustment bolt and adjust end Mounts up or down until aligned with bottom edge of array as marked on the roof, then tighten the Course Adjustment bolt.



5) To set the TopSpeed™ Mount level loosen the Leveling bolt and move the clamp up or down, then tighten the Leveling bolt and torque to 16 ft-lb.




6) Pull string line tight from one corner mount to opposite corner mount to align and level all TopSpeed™ Mounts between the end mounts.

### Install Note:



Use the string line alignment feature on Mounts to level and align the Mounts.

# TopSpeed™ Mount Skirt Installation


## INSTALLATION INSTRUCTIONS




7) Universal Spacers will need to be added to Mounts and Clamps where Skirt will be installed.



8) Install Universal Skirt by holding the skirt in Mount, sliding Skirt to align with array layout marks, and clamping skirt into mount.



9) Use TopSpeed™ Clamps to connect multiple lengths of Array Skirt.



### Install Note:

Optionally use Universal Links to connect lengths of Array Skirt.


## Required Tools

- Socket Wrench
- Torque Wrench
- 1/2" Socket
- Electrician Tools


## Materials Included

### Smart Clips


- 1 (1) Smart Clip [(2) PV Wire, (1) Enphase IQ Cable]
- 2 (1) Smart Clip XL [(6) PV Wire, (4) Enphase IQ]
- 3 (1) Wire Saver [(1) PV Wire]



Smart Clip




Smart Clip XL




Wire Saver

## INSTALLATION INSTRUCTIONS - GROUND LUG


The SnapNrack Ground Lug to be used in accordance with the National Electric Code, ANSI/NFPA 70.




1) Ground Lug (242-92202) can be attached anywhere along the module frame or any TopSpeed™ Mount near the Junction Box. Torque module clamping bolt to 8 ft-lb.



2) Run 10 - 6 AWG, solid, bare copper GEC into Ground Lug channel, torque wire clamping bolt to 8 ft-lb.




3) Run bare, solid EGC from Ground Lug R to Junction Box, bond bare EGC to stranded EGC in Junction Box. For details on installing the Junction Box reference the **Junction Box Installation Manual**.




4) Optionally; Install Ground Lug on the Mount Landing Pad at the top of the array. Run bare copper between ground lug and Junction Box.

## INSTALLATION INSTRUCTIONS - SMART CLIPS

SmartClip and SmartClip XL should be used to route conductors in a neat and workmanlike manner away from all non-bonded components and support the conductors adequately to eliminate potential damage.



1) Use SnapNrack Smart Clip II to manage up two PV wires inside the module frame while prepping out the modules on the ground or installing modules on the roof.



2) Use SnapNrack Smart Clip XL to manage larger bundles of PV wire; up to 6 PV wires per clip



# MLPE & RSD Installation

## Required Tools

- Socket Wrench
- Torque Wrench
- 1/2" Socket

## Materials Included - MLPE Rail Attachment Kit


- 1 (1) SnapNrack MLPE Frame Attachment Top
- 2 (1) SnapNrack MLPE Frame Attachment Bottom
- 3 (1) 5/16"-18 X 3/4" Serrated Flange Bolt SS
- 4 (1) SnapNrack Smart Clip
- 5 (1) SnapNrack MLPE Frame Attachment Coil Spring SS



## Materials Included


### SolarEdge Frame Mount

- 1 (1) SolarEdge Optimizer w/ Frame-Mounted Module Add-On




### Enphase Frame Mount

- 1 (1) Enphase Microinverter
- 2 (1) Enphase Frame Mount




## INSTALLATION INSTRUCTIONS - SNAPNRACK MLPE FRAME ATTACHMENT KIT


SnapNrack MLPE Frame Attachment kit are used to attach module level performance enhancing devices, and other devices such as an SRD (rapid shutdown device), directly to module frames, and provide integrated grounding/bonding for Devices grounded through metal back plate. (Refer to the list of tested MLPE devices on page XX of this manual).



1) Slide the backplate channel of the MLPE device under the MLPE Frame Attachment Kit bolt. The MLPE mounting plate should rest against the MLPE mounting plate backstop on the MLPE Frame Attachment Kit.



2) Position the MLPE Frame Attachment Kit on the module frame flange in a location that will not interfere with mounting system components. The module frame flange should rest against the module flange backstop on the MLPE Frame Attachment Kit.



3) Tighten the mounting bolt on the MLPE Frame Attachment Kit to 12 lb-ft (144 lb-in).




### Install Note:

The MLPE Frame Attachment Kit bonds the following components: Module Frame, MLPE backplate and Smart Clip.




### Install Note:

Avoid blocking module frame drainage holes when installing the MLPE Frame Attachment Kit.




4) Connect the module leads to the input connectors on the MLPE device and manage conductors with the integrated Smart Clip.


## INSTALLATION INSTRUCTIONS - SOLAREEDGE FRAME MOUNT



1) Locate the SolarEdge optimizer with Frame-Mounted Module Add-On at a location on the module frame that will not interfere with the TopSpeed™ Mounts.



2) Install the optimizer mounting plate onto the module frame and tighten hardware to 11 ft-lbs.




3) Connect the module leads to the input connectors on the optimizer and manage conductors with SnapNrack Smart Clips.




### Install Note:

If module is mounted in portrait, install MLPE on long side, short side for landscape.

## INSTALLATION INSTRUCTIONS - ENPHASE FRAME MOUNT



1) Locate the Enphase Frame Mount bracket clamp at a location on the module frame that will not interfere with the TopSpeed™ Mounts.




2) Slide the microinverter unit onto the bracket clamp, then move it slightly to the left.



### Install Note:

The microinverter mounting flange should be on the outside of the module frame.



3) Tighten the hardware to 13 ft-lbs.

4) Connect module leads to microinverter DC connectors.



### Install Note:

Refer to the Enphase Frame Mount installation guide for additional instructions.


# Module Installation

## Required Tools

- Socket Wrench
- Torque Wrench
- 1/2" Socket
- Roofing Sealant



## Materials Included

- ① SnapNrack TopSpeed™ Mount
- ② SnapNrack TopSpeed™ Clamp



## Other Materials Required

- ② SnapNrack Smart Clip (2-5 per module)  
*See Wire Management section for details*
- ③ SnapNrack Smart Clip XL (10-20 per array)  
*See Wire Management section for details*



# Module Installation

snapnrack.com

## INSTALLATION INSTRUCTIONS - BOTTOM ROW


### Recommended Best Practice:

**Attach all TopSpeed™ mounts as the modules are being prepped with MLPEs on the ground. Attach Mounts before attaching MLPEs to simplify wire management.**


### Install Note:

It is recommended that module leads and connectors are prepared for installation using SnapNrack Smart Clips before being brought to the rooftop.


- With no MLPE, secure module leads to module frame to allow access to connectors while modules are installed
- Secure MLPE device to module frame with SnapNrack MLPE Frame Attachment Kit and connect module leads to MLPE, and manage leads by positioning connectors to allow access during installation





1) Rest downslope edge of module on the Mounts and/or Clamps position module so side edge is flush with marked edge of array layout or Skirt.



2) Lower upslope edge of module while simultaneously applying slight pressure to seat module into Mounts and/or Clamps.



3) When module is level with roof verify the Speedseal™ portion of the TopSpeed™ Mounts are positioned entirely on one course of composition. If required listen the 1/2" nut and adjust the base as needed then tighten the bolt.




4) Lift the upslope edge of the module and fill the SpeedSeal™ reservoir with roofing sealant.


### Install Note:

Roof sealant should be expelled from both vents of the TopSpeed™ Mount as it is installed to assure the proper amount of roof sealant has been applied. If sealant is not expelled from all four vents, remove TopSpeed™ Mount, add more sealant to the cavity, then reinstall.


## INSTALLATION INSTRUCTIONS - BOTTOM ROW



5) Lower the module to the roof and drive the (4) pre installed Snaprack #14 Wood Screws with 1/2" hex head into the roof sheathing.



6) Repeat steps 1 through 5 for additional modules in the array.



7) For staggered arrays and arrays with mixed orientation, use the TopSpeed™ Clamp as needed to support the modules.

### Install Note:

Roof sealant should be expelled from both vents of the TopSpeed™ Mount as it is installed to assure the proper amount of roof sealant has been applied. If sealant is not expelled from both vents, remove TopSpeed™ Mount, add more sealant to the cavity, then reinstall.

When installing a TopSpeed™ Clamp for support of an over cantilevered module, the clamp shall be installed 2-6" from the edge of the upslope (cantilevered) module.



# Grounding Specifications

## GROUND PATH DETAILS


All TopSpeed™ components in the fault current ground path have been Certified to be used multiple times for grounding/bonding. The UL 2703 Listing does not specify a maximum number of uses for the Mount, Link, or Ground Lug. Review the requirements of the National Electrical Code (NEC) Article 250 to select the appropriate Equipment Grounding Conductor size based on the short-circuit current of the PV system.

When using Ground Lug R the following components are part of the fault current ground path:


- SnapNrack, TopSpeed™ Mount
- SnapNrack, TopSpeed™ Clamp





## GROUNDING METHOD DETAILS




1) Row to row module bonding provided by bonding clips in Mount assembly and Clamp assembly.



2) Column to column bonding provided by Universal Skirt and bonding clips in the Clamp assembly and/or the RL Universal Link assembly.  
Module heights evaluated for bonding with Link Bonding Clamps: 40mm, 38mm, 35mm, 32mm, 30mm



3) Each continuous array is connected to Equipment Grounding Conductor through Ground Lug (242-92202) installed on one module per array.



## GROUNDING MARKING DETAILS

The Ground Lug is marked with the ground symbol.

Optionally; Install Ground Lug on the Mount Landing Pad at the top of the array.

# Maintaining the Grounding Bonding When Removing a Module

## INSTRUCTION FOR MAINTAINING THE GROUNDING BONDING WHEN REMOVING A MODULE FOR SERVICING

**CAUTION:** Module removal may disrupt the bonding path and could introduce the risk of electric shock. Additional steps may be required to maintain the bonding path. Modules should only be removed by qualified persons in compliance with the instructions in this manual.

Module removal is not presented as a frequently expected occurrence and will not be required as part of routine maintenance.


Scenarios that could result in a disruption of the bonding path are described, for example irregularly-shaped arrays, arrays consisting of individual rows, and any other scenario where module removal could disrupt the bonding path. In most cases, the removal of a module for servicing will not disturb or break grounding continuity. If a module is to be removed that will break continuity, these are the steps that must be taken to maintain a continuously bonded SnapNrack TopSpeed™ System.

### Required Tools

- Socket Wrench
- Torque Wrench
- 1/2" Socket
- 7/16" Socket

### Required Materials

- ① #10 Or Larger Bare Copper Conductor
- ② SnapNrack Ground Lug part no. 242-92202
- ③ IlSCO Part No. SGB-4
- ④ DnoRaxx Dynobond™




# Maintaining the Grounding Bonding When Removing a Module

## JUMPER ASSEMBLY INSTRUCTION & INSTALLATION

**CAUTION:** Do Not Remove the Module until the Jumper is installed


1) Identify the existing ground path at the location of module removal and choose an appropriate length of #10 bare copper to bridge the soon to be broken ground path.



*Example of assembled bonding jumper using (2) SnapNrack Ground Lugs*

2) Attach one ground lug to each end of #10 bare copper wire. See recommended options below:

1. (2) SnapNrack Ground Lug part no. 242-92202
2. (2) IlSCO part no. SGB-4
3. (1) DroRaxx DynoBond™



3) Before the module is removed, attach the assembled bonding jumper. Depending on where the module will be removed and choice of ground lug, jumper attachment locations will vary.

- SnapNrack Ground Lug part no. 242-92202 or IlSCO SGB-4 lugs can be attached to module frames or anywhere on the TopSpeed™ Mount.
- DynoRaxx DynoBond™ is approved and appropriate when a short bonding jumper is needed from module to module.

4) Service the array. With the bonding jumper installed, it is now safe to remove the module for service or maintenance.

5) After Servicing the array reinstall the module and original ground path. Only then Remove the bonding jumper.

**Caution:** Do not remove the bonding jumper until original ground path is established.

## APPROVED MODULE & MLPE INFORMATION

SnapNrack TopSpeed™ System has been tested with the following UL Listed module series: The SnapNrack TopSpeed™ System employs top-down clamps and links which have been evaluated for frame-to-system bonding, at specific mounting torques and with the specific module series listed below. All wattage values are covered.

Module manufacturer approval letters can be found at [www.snapnrack.com](http://www.snapnrack.com).

Manufacturer	Model	
Aptos Solar	DNA-120-MF23-XXX	DNA-120-BF26-XXXW
	DNA-120-BF23-XXX	DNA-144-BF26-XXXW
	DNA-144-MF23-XXX	DNA-108-BF10-xxxW
	DNA-144-BF23-XXX	DNA-120-BF10-xxxW
	DNA-120-MF26-XXXW	DNA-108-MF10-xxxW
	DNA-144-MF26-XXXW	
Boviet Solar	BVM7612M-XXX-H-HC-BF-DG	
Canadian Solar	CS6K-XXX-M	CS1H-XXX-MS
	CS6K-XXX-M-SD	CS1H-XXX-MS-AB
	CS6K-XXX-P	CS3W-XXX-P
	CS6K-XXX-P-SD	CS3N-XXX-MS
	CS6K-XXX-MS	CS1Y-XXX-MS
	CS3K-XXX-P	CS3W-MB-AG
	CS3K-XXX-MS	CS3Y-MB-AG
	CS3U-XXX-MS	CS6W-XXXMB-AG
	CS3U-XXX-P	CS6R-XXXMS-HL
	CS1K-XXX-MS	CS3W-XXX-MS
CertainTeed	CTXXXHC11-06	
Chint Solar	CHSM6612M-XXX	CHSM72M-HC-XXX* (Astro 4)
	CHSM6612M(BL)-XXX	CHSM72M-HC-XXX* (Astro 5)
	CHSM6612M/HV-XXX	
Dehui Solar	DH-M760B-XXXW	DH-M760F-XXXW
	DH-M760W-XXXW	DH-M772F-XXXW
	DH-M772W-XXXW	
Freedom Forever	FF-MP-BBB-xxx	
Hanwha Q Cells	Q.PEAK DUO-G5-XXX	Q.PEAK DUO G10-XXX
	Q.PEAK DUO-BLK-G5-XXX	Q.PEAK DUO BLK G10-XXX
	Q.PLUS DUO-G5-XXX	Q.PEAK DUO G10+-XXX
	Q.PEAK DUO-G7-XXX	Q.PEAK DUO BLK G10+-XXX
	Q.PEAK DUO-BLK-G7-XXX	Q.PEAK DUO XL-G10.3-XXX
	Q.PEAK DUO-G7.2-XXX	Q.PEAK DUO XL-G10.c-XXX
	Q.PEAK DUO-G6+-XXX	Q.PEAK DUO XL-G10.d-XXX
	Q.PEAK DUO-BLK-G6+-XXX	Q.PEAK DUO L-G8.3/BFG-XXX
	Q.PEAK DUO-G6-XXX	Q.PEAK DUO L-G8.3/BGT-XXX
	Q.PEAK DUO-BLK-G6-XXX	Q.PEAK DUO ML-G10-XXX
	Q.PEAK DUO-G8+-XXX	Q.PEAK DUO BLK ML-G10+-XXX
	Q.PEAK DUO-BLK-G8+-XXX	Q.PEAK DUO ML-G10+-XXX

# Appendix A

Manufacturer	Model	
Hanwha Q Cells	Q.PEAK DUO-G8-XXX	Q.PEAK DUO BLK ML-G10-XXX
	Q.PEAK DUO-BLK-G8-XXX	Q.PEAK DUO ML-G10.a+-XXX
	Q.PEAK DUO BLK-G6+/AC-XXX	Q.PEAK DUO BLK ML-G10.a+-XXX
	Q.PEAK DUO-ML-G9-XXX	Q.PEAK DUO ML-G10.a-XXX
	Q.PEAK DUO-BLK-ML-G9-XXX	Q.PEAK DUO BLK ML-G10.a-XXX
	Q.PEAK DUO-BLK-G9-XXX	Q.PEAK DUO BLK G10+/AC XXX
	Q.PEAK DUO-BLK-ML-G9+-XXX	Q.PEAK DUO BLK G10+/HL XXX
	Q.PEAK DUO-ML-G9+-XXX	Q.PEAK DUO BLK ML-G10+/t-XXX
	Q.PEAK DUO-BLK-ML-G9+-XXX	Q.PEAK DUO XL-G11.3 XXX
	Q.PEAK DUO XL-G9.2-XXX	Q.PEAK DUO XL-G11.3 BFG XXX
	Q.PEAK DUO XL-G9.3-XXX	Q.TRON-G1+ XXX
	Q.PEAK DUO XL-G9.3/BFG-XXX	Q.TRON BLK-G1+ XXX
	Q.PEAK DUO XL-G10.2-XXX	Q.TRON M-G2+ XXX
	Q.PEAK DUO XL-G10.3/BFG-XXX	Q.TRON BLK M-G2+ XXX
HT-SAAE	HT60-166M-XXX	HT60-182M-XXX
Heliene	60M-XXX	72M-XXX
	60P-XXX	72P-XXX
"Hyundai (All may be followed by "BK")"	HiA-SXXXMS	HiS-SXXXYI
	HiS-SXXXXY	HiS-SXXXXYH(BK)
	HiN-SxxxXG(BK)	
Hyperion/Runergy	HY-DH108P8-XXX(Y)	HY-DH144N8-XXX
	HY-DH144P8-XXX	HY-DH108N8-XXX
JA Solar	JAM60S09-XXX/PR	JAM72S10-XXX/PR
	JAM60S10-XXX/MR	JAM72S12-XXX/PR
	JAM60S10-XXX/PR	JAM60S17-XXX/MR
	JAM60S12-XXX/PR	JAM54S30-XXX/MR
	JAM72S09-XXX/PR	JAM54S31-XXX/MR
	JAM72S10-XXX/MR	JAM72D30-XXX/MB
Jinko Solar	JKMXXXM-60	JKMXXXP-72-V
	JKMXXXM-60L	JKMXXXPP-72
	JKMXXXM-60HL	JKMXXXPP-72-V
	JKMXXXM-60HBL	JKMSXXXP-72
	JKMXXXP-60	JKMXXXM-72HL-V
	JKMXXXP-60-J4	JKMXXXM-72HL-TV
	JKMXXXP-60-V	JKMXXXM-72HBL
	JKMXXXP-60B-J4	JKMXXXM-6TL3-B
	JKMXXXPP-60	JKMXXXM-6RL3-B
	JKMXXXPP-60-V	JKMXXXM-7RL3-V
	JKMXXXM-72	JKMXXXM-7RL3-TV
	JKMXXXM-72L-V	JKMXXXM-72HL4-V
	JKMXXXP-72	JKMXXXM-72HL4-TV
LG	LGXXXN1C-A5	LGXXXA1C-V5
	LGXXXN1K-A5	LGXXXM1C-L5
	LGXXXQ1C-A5	LGXXXM1K-L5
	LGXXXQ1K-A5	LGXXXN1C-N5

# Appendix A

Manufacturer	Model	
LG	LGXXXS1C-A5	LGXXXN1K-L5
	LGXXXN2C-B3	LGXXXN1K-A6
	LGXXXN2W-B3	LGXXXN1C-A6
	LGXXXN1C-G4	LGXXXN1W-A6
	LGXXXN1K-G4	LGXXXQ1C-A6
	LGXXXS1C-G4	LGXXXQ1K-A6
	LGXXXN2C-G4	LGXXXM1K-A6
	LGXXXN2K-G4	LGXXXM1C-A6
	LGXXXN2W-G4	LGXXXA1C-A6
	LGXXXS2C-G4	LGXXXQAC-A6
	LGXXXS2W-G4	LGXXXQAK-A6
	LGXXXN1C-V5	LGXXXN1K-B6
	LGXXXN1W-V5	LGXXXN2W-E6
	LGXXXN2T-V5	LGXXXN2T-E6
	LGXXXN2T-J5	LGXXXN1K-E6
	LGXXXN1T-V5	LGXXXN3K-V6
Longi	LR6-60-XXXM	LR4-60HPB-XXXM
	LR6-60BK-XXXM	LR4-60HIB-XXXM
	LR6-60HV-XXXM	LR4-60HPH-XXXM
	LR6-60PB-XXXM	LR4-60HIH-XXXM
	LR6-60PE-XXXM	LR6-60HIH-XXXM
	LR6-60PH-XXXM	LR6-60HIB-XXXM
	LR6-60HPB-XXXM	LR4-72HPH-XXXM
	LR6-60HPH-XXXM	
Meyer Burger	Meyer Burger Black*	Meyer Burger White*
mSolar	TXI6-XXX120BB	
Mission Solar	MSEXXXSO5T	MSEXXXSQ4S
	MSEXXXSO5K	MSEXXXSR8K
	MSEXXXSQ5T	MSEXXXSR8T
	MSEXXXSQ5K	MSEXXXSR9S
	MSEXXXMM4J	MSE60AXXX
	MSEXXXMM6J	MSEXXXSX5K
	MSEXXXSO6W	MSEXXXSX5T
	MSEXXXSO4J	MSEXXXSX6S
	MSEXXXSO6J	MSEXXXSX6W
	MSEXXXSQ6S	MSEXXXSX5R
Next Energy Alliance	USNEA-XXXM3-60	USNEA-XXXM3-72
	USNEA-XXXM3B-60	USNEA-XXXM3B-72
Panasonic	VBHNXXXKA03	VBHXXXRA18N
	VBHNXXXKA04	VBHXXXRA03K
	VBHNXXXSA17	EVPVXXX(K)
	VBHNXXXSA18	EVPVXXXH
	VBHN325SA17E	EVPVXXXPK

# Appendix A

Manufacturer	Model	
Philadelphia Solar	PS-M144(HCBF)-XXXW	PS-M108(HC)-XXXW
	PS-M108(HCBF)-XXXW	
Phono Solar	PSXXXM-20/U	PSxxxM8GF-18/VH
	PSXXXMH-20/U	PSxxxM8GFH-18/VH
	PSxxxM8GF-24/TH	PSxxxM6-24/TH
	PSxxxM8GFH-24/TH	
REC (All may be followed by "BLK" or "BLACK")	RECXXTP2	RECXXTP2SM 72 BLK2
	RECXXTP2-BLK	RECXXXAA
	RECXXXNP	RECXXTP3M
	RECXXTP2M	RECXXTP4
	RECXXTP2M 72	RECXXXAA Pure
	RECXXTP2M 72 BLK	RECXXXAA Pure-R
	RECXXTP2M 72 BLK2	RECXXXNP2
	RECXXTP2SM 72	RECXXXNP3
	RECXXTP2SM 72 BLK	
SEG Solar	SEG-400-BMB-HV	SEG-xxx-BMD-HV
	SEG-400-BMB-TB	SEG-xxx-BMD-TB
Silfab	SLAXXX-M	SILXXXNT
	SLAXXX-P	SILXXXHL
	SSAXXX-M	SILXXXBK
	SSAXXX-P	SILXXXNX
	SILXXXBL	SILXXXNU
	SILXXXML	SILXXXHC
	SILXXXNL	SILXXXHN
	SLGXXX-M	SILXXXBG
	SLGXXX-P	SIL-xxxHC+
	SSGXXX-M	SIL-xxxHM
	SSGXXX-P	
Solaria	Solaria PowerXT-XXXR-PX	Solaria PowerXT-XXXR-PM
	Solaria PowerXT-XXXR-BX	Solaria PowerXT-XXXR-PM-AC
	Solaria PowerXT-XXXR-AC	
Sunpower	SPR-AXXX-G-AC	SPR-MXXX-H-AC
	SPR-AXXX	SPR-MXXX
	SPR-AXXX-BLK-G-AC	SPR-MXXX-BLK-H-AC
	SPR-AXXX-BLK	SPR-MXXX-BLK
SunSpark	SST-XXXM3-60	SST-XXXM3-72
	SST-XXXM3B-60	SST-XXXM3B-72
Talesun	TP660M-XXX	TP672M-XXX
	TP660P-XXX	TP672P-XXX
Thornova	TS-BB54(XXX)	TS-BG60(XXX)
	TS-BB60(XXX)	TS-BG72(XXX)
	TS-BG54(XXX)	

Manufacturer	Model	
Trina	TSM-XXXDD05(II)	TSMXXXDD05H.05(II)
	TSM-XXXDD05A.05(II)	TSM-XXXDD06M.05(II)
	TSM-XXXDD05A.08(II)	TSM-XXXDE15H(II)
	TSM-XXXDD05A.082(II)	TSM-XXXDE15M(II)
	TSM-XXXPA05	TSMXXXDE06X.05(II)
	TSM-XXXPA05.05	TSMXXXDE09.05
	TSM-XXXPA05.08	TSM-XXXDE15V(II)
	TSM-XXXPD05	TSM-XXXDEG15VC.20(II)
	TSM-XXXPD05.002	TSM-XXXDEG18MC.20(II)
	TSM-XXXPD05.05	TSM-XXXDEG19C.20
	TSM-XXXPD05.05S	TSM-XXXDEG21C.20
	TSM-XXXPD05.08	TSM-XXXDE09C.05
	TSM-XXXPD05.082	TSM-XXXDE09C.07
	TSM-XXXPD05.08D	TSM-xxxNE09RC.05
	TSM-XXXPD05.08S	
Vikram Solar	SOMERA VSMHBB.60.XXX.05	PREXOS VSMDHT.60.XXX.05
	SOMERA VSMH.72.XXX.05	PREXOS VSMDHT.72.XXX.05
VSUN	VSUNXXX-144BMH-DG	VSUNXXX-108BMH
	VSUNXXX-120BMH	
ZNShine	ZXM6-60-XXX/M	ZXM6-NH144-XXXM
	ZXM6-NH120-XXXM	ZXM7-SH108-XXXM
	ZXM7-SHLDD144-XXXM	

**SnapNrack TopSpeed™ has been tested with the following Module Level Power Electronic (MLPE) devices:**

SnapNrack TopSpeed™ mounting systems has been tested with the following UL/NRTL Listed Module Level Power Electronic (MLPE) Devices. The back plates of the MLPEs have been evaluated for bonding to TopSpeed™ through the SnapNrack MLPE Frame Attachment Kit, model 242-02151.

MLPE Manufacturer	Model	
AP Smart	RSD-S-PLC	
Celestica International	DG-006-F001201x	DG-006-F001401x
Delta Electronics	GPI00010105	
Enphase	C250	IQ7PLUS-72-2-US
	M215	IQ7PLUS-72-B-US
	M250	IQ8-60
	IQ6-60-2-US	IQ8PLUS-72
	IQ6PLUS-72-2-US	IQ8A-72
	IQ7-60-2-US	IQ8H-208-72
	IQ7-60-B-US	IQ8H-240-72
Generec	S2502	
Ginlong Technologies	Solis-RSD-1G	
	Solis-MLRSD-R1-1G	Solis-MLRSD-R2-1G

# Appendix A

MLPE Manufacturer	Model	
SolarEdge	P300-5NC4ARS	P320-5NC4ARS
	P370-5NC4AFS	P400-5NC4AFS
	P320	P340
	P370	P400
	P401	P405
	P485	P505
	P730	P800p
	P850	P860
	P950	P1100
	P1101	S440
	S500	
SMA	RSB-2S-US-10	
Tigo	TS4-R-F	TS4-R-M
	TS4-R-O	TS4-R-S
	TS4-R-M-DUO	TS4-R-O-DUO
	TS4-R-S-DUO	TS4-A-F
	TS4-A-2F	TS4-A-O
	TS4-A-S	

# Hi-MO **5m**

## LR5-54HPB 400~420M

- Suitable for distributed projects
- Advanced module technology delivers superior module efficiency
  - M10 Gallium-doped Wafer
  - Integrated Segmented Ribbons
  - 9-busbar Half-cut Cell
- Excellent outdoor power generation performance
- Aesthetic appearance with all black module design



12-year Warranty for Materials and Processing



25-year Warranty for Extra Linear Power Output

### Complete System and Product Certifications

IEC 61215, IEC 61730, UL 61730

ISO9001:2015: ISO Quality Management System

ISO14001: 2015: ISO Environment Management System

ISO45001: 2018: Occupational Health and Safety

IEC62941: Guideline for module design qualification and type approval

# LONGI



**21.5%**  
MAX MODULE  
EFFICIENCY

**0~3%**  
POWER  
TOLERANCE




**<2%**  
FIRST YEAR  
POWER DEGRADATION

**0.55%**  
YEAR 2-25  
POWER DEGRADATION

**HALF-CELL**  
Lower operating temperature

## Additional Value

25-Year Power Warranty



## Mechanical Parameters

Cell Orientation	108 (6×18)
Junction Box	IP68, three diodes
Output Cable	4mm <sup>2</sup> , ±1200mm length can be customized
Glass	Single glass, 3.2mm coated tempered glass
Frame	Anodized aluminum alloy frame
Weight	20.8kg
Dimension	1722×1134×30mm
Packaging	36pcs per pallet / 216pcs per 20' GP / 936pcs per 40' HC

## Electrical Characteristics

STC : AM1.5 1000W/m<sup>2</sup> 25°C    NOCT : AM1.5 800W/m<sup>2</sup> 20°C 1m/s    Test uncertainty for Pmax: ±3%

Module Type	LR5-54HPB-400M		LR5-54HPB-405M		LR5-54HPB-410M		LR5-54HPB-415M		LR5-54HPB-420M	
	STC	NOCT	STC	NOCT	STC	NOCT	STC	NOCT	STC	NOCT
Maximum Power (Pmax/W)	400	299.0	405	302.7	410	306.5	415	310.2	420	313.9
Open Circuit Voltage (Voc/V)	36.90	34.70	37.15	34.93	37.40	35.17	37.65	35.40	37.89	35.63
Short Circuit Current (Isc/A)	13.72	11.09	13.78	11.14	13.84	11.19	13.91	11.24	13.97	11.30
Voltage at Maximum Power (Vmp/V)	30.94	28.74	31.18	28.96	31.42	29.19	31.66	29.41	31.90	29.63
Current at Maximum Power (Imp/A)	12.93	10.40	12.99	10.45	13.05	10.50	13.11	10.55	13.17	10.59
Module Efficiency(%)	20.5		20.7		21.0		21.3		21.5	

## Operating Parameters

Operational Temperature	-40°C ~ +85°C
Power Output Tolerance	0 ~ 3%
Voc and Isc Tolerance	±3%
Maximum System Voltage	DC1000V (IEC/UL)
Maximum Series Fuse Rating	25A
Nominal Operating Cell Temperature	45±2°C
Protection Class	Class II
Fire Rating	UL type 1 or 2 IEC Class C

## Mechanical Loading

Front Side Maximum Static Loading	5400Pa
Rear Side Maximum Static Loading	2400Pa
Hailstone Test	25mm Hailstone at the speed of 23m/s

## Temperature Ratings (STC)

Temperature Coefficient of Isc	+0.050%/°C
Temperature Coefficient of Voc	-0.265%/°C
Temperature Coefficient of Pmax	-0.340%/°C



# IQ8 and IQ8+ Microinverters

Our newest IQ8 Microinverters are the industry’s first microgrid-forming, software-defined microinverters with split-phase power conversion capability to convert DC power to AC power efficiently. The brain of the semiconductor-based microinverter is our proprietary application-specific integrated circuit (ASIC), which enables the microinverter to operate in grid-tied or off-grid modes. This chip is built using advanced 55-nm technology with high-speed digital logic and has superfast response times to changing loads and grid events, alleviating constraints on battery sizing for home energy systems.



Part of the Enphase Energy System, IQ8 Series Microinverters integrate with the IQ Battery, IQ Gateway, and the Enphase App monitoring and analysis software.



IQ8 Series Microinverters redefine reliability standards with more than one million cumulative hours of power-on testing, enabling an industry-leading limited warranty of up to 25 years.



Connect PV modules quickly and easily to IQ8 Series Microinverters using the included Q-DCC-2 adapter cable with plug-and-play MC4 connectors.



IQ8 Series Microinverters are UL Listed as PV rapid shutdown equipment and conform with various regulations, when installed according to the manufacturer’s instructions.

## Easy to install

- Lightweight and compact with plug-and-play connectors
- Power line communication (PLC) between components
- Faster installation with simple two-wire cabling

## High productivity and reliability

- Produce power even when the grid is down\*
- More than one million cumulative hours of testing
- Class II double-insulated enclosure
- Optimized for the latest high-powered PV modules

## Microgrid-forming

- Compliant with the latest advanced grid support\*\*
- Remote automatic updates for the latest grid requirements
- Configurable to support a wide range of grid profiles
- Meets CA Rule 21 (UL 1741-SA) and IEEE 1547:2018 (UL 1741-SB)

### NOTE:

- IQ8 Microinverters cannot be mixed with previous generations of Enphase microinverters (IQ7 Series, IQ6 Series, and so on) in the same system.
- IQ Microinverters ship with default settings that meet North America’s IEEE 1547 interconnection standard requirements. Region-specific adjustments may be requested by an Authority Having Jurisdiction (AHJ) or utility representative according to the IEEE 1547 interconnection standard. An IQ Gateway is required to make these changes during installation.

\*Meets UL 1741 only when installed with IQ System Controller 2 or 3.  
 \*\*IQ8 and IQ8+ support split-phase, 240 V installations only.

# IQ8 and IQ8+ Microinverters

INPUT DATA (DC)		UNITS	IQ8-60-2-US	IQ8PLUS-72-2-US
Commonly used module pairings <sup>1</sup>	W		235–350	235–440
Module compatibility	—	To meet compatibility, PV modules must be within maximum input DC voltage and maximum module $I_{sc}$ listed below. Module compatibility can be checked at <a href="https://enphase.com/installers/microinverters/calculator">https://enphase.com/installers/microinverters/calculator</a> .		
MPPT voltage range	V		27–37	27–45
Operating range	V		16–48	16–58
Minimum/Maximum start voltage	V		22/48	22/58
Maximum input DC voltage	V		50	60
Maximum continuous input DC current	A		10	12
Maximum input DC short-circuit current	A			25
Maximum module ( $I_{sc}$ )	A			20
Overtoltage class DC port	—			II
DC port backfeed current	mA			0
PV array configuration	—	Ungrounded array; no additional DC side protection required; AC side protection requires maximum 20 A per branch circuit.		
OUTPUT DATA (AC)		UNITS	IQ8-60-2-US	IQ8PLUS-72-2-US
Peak output power	VA		245	300
Maximum continuous output power	VA		240	290
Nominal grid voltage (L-L)	V		240, split-phase (L-L), 180°	
Minimum and Maximum grid voltage <sup>2</sup>	V		211–264	
Maximum continuous output current	A		1.0	1.21
Nominal frequency	Hz			60
Extended frequency range	Hz			47–68
AC short-circuit fault current over three cycles	Arms			2
Maximum units per 20 A (L-L) branch circuit <sup>3</sup>	—		16	13
Total harmonic distortion	%			<5
Overtoltage class AC port	—			III
AC port backfeed current	mA			30
Power factor setting	—			1.0
Grid-tied power factor (adjustable)	—			0.85 leading ... 0.85 lagging
Peak efficiency	%			97.7
CEC weighted efficiency	%			97
Nighttime power consumption	mW		23	25
MECHANICAL DATA				
Ambient temperature range			-40°C to 60°C (-40°F to 140°F)	
Relative humidity range			4% to 100% (condensing)	
DC connector type			MC4	
Dimensions (H × W × D)			212 mm (8.3 in) × 175 mm (6.9 in) × 30.2 mm (1.2 in)	
Weight			1.08 kg (2.38 lbs)	
Cooling			Natural convection—no fans	
Approved for wet locations			Yes	
Pollution degree			PD3	
Enclosure			Class II double-insulated, corrosion-resistant polymeric enclosure	
Environmental category/UV exposure rating			NEMA Type 6/Outdoor	

(1) No enforced DC/AC ratio.

(2) Nominal voltage range can be extended beyond nominal if required by the utility.

(3) Limits may vary. Refer to local requirements to define the number of microinverters per branch in your area.

COMPLIANCE

Certifications

CA Rule 21 (UL 1741-SA), UL 62109-1, IEEE 1547:2018 (UL 1741-SB), FCC Part 15 Class B, ICES-0003 Class B, CAN/CSA-C22.2 NO. 107.1-01.  
This product is UL Listed as PV rapid shutdown equipment and conforms with NEC 2014, NEC 2017, NEC 2020, and NEC 2023 section 690.12 and C22.1-2018 Rule 64-218 rapid shutdown of PV Systems, for AC and DC conductors, when installed according to the manufacturer's instructions.

## Revision history


REVISION	DATE	DESCRIPTION
DSH-00207-3.0	February 2024	Updated the information about IEEE 1547 interconnection standard requirements.
DSH-00207-2.0	October 2023	Included NEC 2023 specification in the “Compliance” section.
DSH-00207-1.0	September 2023	Updated module compatibility specification.

01/20/26

To whom it may concern,

- Justification of panels on the front of the house and heat map.

### Monthly energy consumption for Address vs the proposed system monthly production



Overview


Segment	Modules	Size	Production	Per module	ASA	TSRF	Consumption	PV Offset	Area	Coverage	Perimeter
All total	14	5.67 kW	3,689 kWh	264 kWh	48.02%	45%	0 kWh	0%	1893 ft²	16.13%	144 (ft)

Nearest weather station: 724050, WASHINGTON DC REAGAN AP, VA NSRDB (7.61 mi)

Monthly Average Solar Access



Monthly Consumption and Production (kWh)



- The home had an estimated annual usage of roughly 17,420 kWh in 2025. Our proposed system is estimated to have 3,689 kWh in annual production.


The panels will vary in production based on their location on the structure, but this estimated production for a **14**-panel system breaks down to roughly 264 kWh per panel annually.

- The 5 panels on the lower south facing roof plane have an average of 206 kWh per panel with an estimated annual production of 1,028 kWh. The 2 panels on the upper east facing roof plane have an average of 219 kWh per panel with an estimated annual production of 439 kWh. The 7 panels on the upper south facing roof plane have an average of 317 kWh per panel with an estimated annual production of 2,222 kWh.

**Justification for the Placement of the panels.**

- As noted above, the panels on the upper south of the home have a higher average kWh per module compared to modules on the lower part of the house and on the side of the house.
- There are also trees on the front of the property that would be limiting visibility from the right-of-way

**Shade Map.**




Thank you,  
**Andrew Tam**  
Design Engineer.

Critter Guard



David C. Hernandez, PE  
 Digitally signed by David C. Hernandez, PE  
 Date: 2025.12.19 17:37:28 -05:00



**KEY** FIRE SAFETY ZONE

3' PATHWAYS FROM LOWEST ROOF EDGE TO RIDGE PROVIDED PER R324.6.1

1'6" PATHWAYS PROVIDED ON BOTH SIDES OF RIDGE PER R324.6.2

PLAN VIEW TOTAL ROOF AREA: 1893 SQFT

SOLAR ARRAY AREA: 294.28 SQFT

THE SOLAR ARRAY IS 15.5% OF THE PLAN VIEW TOTAL ROOF AREA

**NOTES:**

1. THE SYSTEM SHALL INCLUDE (14) LONGI LR5-54HPB-405M.
2. SNAPNRACK TOPSPEED WILL BE INSTALLED IN ACCORDANCE WITH SNAPNRACK INSTALLATION MANUAL.
3. REFER TO STRUCTURAL DRAWING FOR SECTIONS MARKED AND ADDITIONAL NOTES.

**SOLAR PANEL LAYOUT**

Scale: 1/8" = 1'-0"

**SolarEnergyWorld**  
 Because Tomorrow Matters

Solar Energy World LLC.  
 14880 Sweitzer Lane  
 Laurel, MD 20707  
 (888) 497-3233

**Disclaimer:**  
 This drawing is the property of Solar Energy World Inc. The information herein contained shall be used for the sole benefit of Solar Energy World. It shall not be disclosed to others outside the recipient's organization, in whole or in part, without the written permission of Solar Energy World, except in connection with the sale and use of the respective Solar Energy equipment.

Building Code: International Residential Code (IRC) 2021

Electrical Code: National Electrical Code (NEC) 2017

Wind Speed: 115 MPH	Snow Load: 30 PSF
---------------------	-------------------

Modules: (14) LONGi LR5-54HPB-405M

Inverter(s): (14) IQ8+-72-M-US

DC System Size: 5.670 kW	AC System Size: 4.060 kW
--------------------------	--------------------------

Customer Information  
 Jeremiah Frueauf  
 7013 Poplar Ave  
 Takoma Park, MD 20912


Permit/Lender: None

City: Montgomery	Utility: Pepco
------------------	----------------

Sheet Name: Solar Panel Layout


Drawn By: AO	Date: December 18, 2025
--------------	-------------------------

Scale: AS NOTED	Job Number: MD29711	Sheet: A-1
-----------------	---------------------	------------





**David C. Hernandez, PE**  
 Digitally signed by David C. Hernandez, PE  
 Date: 2025.12.19 17:37:28 -05:00



**SITE PLAN**  
 Scale: 1" = 40'-0"

**SolarEnergyWorld**  
 Because Tomorrow Matters

Solar Energy World LLC.  
 14880 Sweitzer Lane  
 Laurel, MD 20707  
 (888) 497-3233

**Disclaimer:**  
 This drawing is the property of Solar Energy World Inc. The information herein contained shall be used for the sole benefit of Solar Energy World. It shall not be disclosed to others outside the recipient's organization, in whole or in part, without the written permission of Solar Energy World, except in connection with the sale and use of the respective Solar Energy equipment.

Building Code  
 International Residential Code (IRC) 2021

Electrical Code  
 National Electrical Code (NEC) 2017

Wind Speed 115 MPH	Snow Load 30 PSF
-----------------------	---------------------

Modules  
 (14) LONGi LR5-54HPB-405M

Inverter(s)  
 (14) IQ8+-72-M-US

DC System Size 5.670 kW	AC System Size 4.060 kW
----------------------------	----------------------------

Customer Information  
 Jeremiah Frueauf  
 7013 Poplar Ave  
 Takoma Park, MD 20912

Payment/Lender  
 None

AHU Montgomery	Utility Pepco
-------------------	------------------

Sheet Name  
 Site Plan

Drawn By AO	Date December 18, 2025
----------------	---------------------------


Scale AS NOTED	Job Number MD29711	Sheet A-2
-------------------	-----------------------	--------------



PROFESSIONAL CERTIFICATION: I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME AND THAT I AM A FULLY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND. LICENSE NO. 49993 EXP. 10/30/2026

**David C. Hernandez, PE**

Digitally signed by David C. Hernandez, PE  
Date: 2025.12.19 17:37:28 -05:00




**EQUIPMENT LOCATION PLAN**

Scale: NTS

**NOTE:**

EQUIPMENT LOCATION PLAN IS APPROXIMATE, EXACT LOCATION TO BE VERIFIED WITH INSTALLATION CREW AND HOME OWNER AT THE TIME OF INSTALLATION.



**SolarEnergyWorld**  
Because Tomorrow Matters



Solar Energy World LLC.  
14880 Sweitzer Lane  
Laurel, MD 20707  
(888) 497-3233

**Disclaimer:**  
This drawing is the property of Solar Energy World Inc. The information herein contained shall be used for the sole benefit of Solar Energy World. It shall not be disclosed to others outside the recipient's organization, in whole or in part, without the written permission of Solar Energy World, except in connection with the sale and use of the respective Solar Energy equipment.

Building Code	
International Residential Code (IRC) 2021	
Electrical Code	
National Electrical Code (NEC) 2017	
Wind Speed	Snow Load
115 MPH	30 PSF
Modules	
(14) LONGi LR5-54HPB-405M	
Inverter(s)	
(14) IQ8+-72-M-US	
DC System Size	AC System Size
5.670 kW	4.060 kW
Customer Information	
Jeremiah Frueauf 7013 Poplar Ave Takoma Park, MD 20912	
Payment/Lender	
None	
City	Utility
Montgomery	Pepco
Sheet Name	
Equipment Location Plan	
Drawn By	Date
AO	December 18, 2025
Scale	Job Number
AS NOTED	MD29711
Sheet	
E-1	



**David C. Hernandez, PE**  
 Digitally signed by David C. Hernandez, PE  
 Date: 2025.12.19 17:37:28 -05:00



### Structural Details

S1	Rafter	2x10 O.C. 16"
----	--------	---------------

#### NOTES:

- ALL WORK SHALL COMPLY WITH REQUIREMENTS OF INTERNATIONAL RESIDENTIAL CODE (IRC 2021), LOADING CODE (ASCE 7-16), WOOD DESIGN CODE (NDS 2015), AND LOCAL REQUIREMENTS.
- LOAD CRITERIA PER :
  - EXPOSURE CATEGORY "B"
  - GROUND SNOW LOAD,  $P_g = 30$  PSF
  - LATERAL LOAD RISK CATEGORY "II"
  - ULTIMATE DESIGN WIND SPEED = 115 MPH
- SOLAR PANELS AND RACKING SYSTEMS SHALL BE INSTALLED PER MANUFACTURER'S RECOMMENDATION.
- FOLLOW ALL LOCAL AND FEDERAL SAFETY REQUIREMENTS.

### STRUCTURAL ATTACHMENT DETAIL

**SolarEnergyWorld**  
 Because Tomorrow Matters

Solar Energy World LLC.  
 14880 Sweitzer Lane  
 Laurel, MD 20707  
 (888) 497-3233

**Disclaimer:**  
 This drawing is the property of Solar Energy World Inc. The information herein contained shall be used for the sole benefit of Solar Energy World. It shall not be disclosed to others outside the recipient's organization, in whole or in part, without the written permission of Solar Energy World, except in connection with the sale and use of the respective Solar Energy equipment.

Building Code: International Residential Code (IRC) 2021

Electrical Code: National Electrical Code (NEC) 2017

Wind Speed 115 MPH	Snow Load 30 PSF
-----------------------	---------------------

Modules:  
(14) LONGi LR5-54HPB-405M

Inverter(s):  
(14) IQ8+-72-M-US

DC System Size 5.670 kW	AC System Size 4.060 kW
----------------------------	----------------------------

Customer Information:  
 Jeremiah Frueauf  
 7013 Poplar Ave  
 Takoma Park, MD 20912

Permit/Lender:  
None

AHU Montgomery	Utility Peppo
-------------------	------------------


Sheet Name:  
Structural Attachment Details

Drawn By AO	Date December 18, 2025
----------------	---------------------------

Scale AS NOTED	Job Number MD29711	Sheet S-1
-------------------	-----------------------	--------------




**David C. Hernandez, PE**  
 Digitally signed by David C. Hernandez, PE  
 Date: 2025.12.19 17:37:28 -05:00




**SOLAR PANEL FOOTING PLAN R1**

Scale: 1/8" = 1'-0"



**SOLAR PANEL FOOTING PLAN R2**

Scale: 1/8" = 1'-0"



**SOLAR PANEL FOOTING PLAN R3**

Scale: 1/8" = 1'-0"

**KEY**


-  MOUNTS WITHOUT SPACERS
-  MOUNTS WITH SPACERS
-  CLAMPS WITHOUT SPACERS
-  CLAMPS WITH SPACERS

**Bill Of Materials**

Product	Count
Mounts Without Spacers	28
Mounts With Spacers	18
Clamps Without Spacers	0
Clamps With Spacers	6

**NOTES:**

1. SNAPRACK TOPSPEED SHALL BE INSTALLED IN ACCORDANCE WITH SNAPRACK INSTALLATION MANUAL.
2. ADD TOPSPEED CLAMP IF GREATER THAN (SOLAR PANEL LENGTH / 4) FOR LANDSCAPE OR (SOLAR PANEL WIDTH / 4) FOR PORTRAIT
3. NO SOLAR PANEL SHALL CANTILEVER MORE THAN 1/4 SOLAR PANEL LENGTH OR WIDTH DEPENDING ON ORIENTATION, UNLESS FOR MANUFACTURER SPECIFIED CLAMPING ZONE



**SolarEnergyWorld**  
Because Tomorrow Matters


Solar Energy World LLC.  
14880 Sweitzer Lane  
Laurel, MD 20707  
(888) 497-3233

**Disclaimer:**  
 This drawing is the property of Solar Energy World Inc. The information herein contained shall be used for the sole benefit of Solar Energy World. It shall not be disclosed to others outside the recipient's organization, in whole or in part, without the written permission of Solar Energy World, except in connection with the sale and use of the respective Solar Energy equipment.



Building Code International Residential Code (IRC) 2021	
Electrical Code National Electrical Code (NEC) 2017	
Wind Speed 115 MPH	Snow Load 30 PSF
Modules (14) LONGi LR5-54HPB-405M	
Inverter(s) (14) IQ8+-72-M-US	
DC System Size 5.670 kW	AC System Size 4.060 kW
Customer Information Jeremiah Frueauf 7013 Poplar Ave Takoma Park, MD 20912	
Permit/Lender None	
AHJ Montgomery	Utility Pepco
Sheet Name Solar Panel Footing Plan	
Drawn By AO	Date December 18, 2025
Scale AS NOTED	Job Number MD29711
Sheet <b>S-2</b>	

**SMART INVERTERS**

**1 STRING OF 7 MODULES**



**1 STRING OF 7 MODULES**



MODES OF OPERATION:  
SUPPORT FOR SOLAR  
SELF-CONSUMPTION  
TIME-BASED CONTROL &  
BACKUP  
CUSTOMER USING  
BACKUP MODE  
BATTERIES WILL NOT BE  
EXPORTED TO THE GRID


**3-LINE DIAGRAM**

BATTERY SPECIFICATIONS		
BATTER MODEL/# OF UNITS	[1] Franklin aPower 2 BATTERY	
	PER UNIT	TOTAL
USABLE ENERGY CAPACITY	15 kWh	15 kWh
MAX CONTINUOUS OUTPUT POWER	10000 W	10000 W
MAX CONTINUOUS OUTPUT CURRENT (NOMINAL AC VOLTAGE OF 120/240V)	48 A	48 A
LRA SURGE OUTPUT CURRENT (NOMINAL AC VOLTAGE OF 120/240V)	150 A	150 A
MODULE SPECIFICATIONS		
MODEL NUMBER	LR5-54HPB-405M	
PEAK POWER	405 W	
RATED VOLTAGE (V <sub>mpp</sub> )	31.18 V	
RATED CURRENT (I <sub>mp</sub> )	12.99 A	
OPEN CIRCUIT VOLTAGE (V <sub>oc</sub> )	37.15 V	
SHORT CIRCUIT CURRENT (I <sub>sc</sub> )	13.78 A	
MAXIMUM SYSTEM VOLTAGE	1500VDC	
INVERTER SPECIFICATIONS		
MODEL NUMBER	IQ8PLUS-72-M-US	
MAXIMUM DC VOLTAGE	60 V	
MAXIMUM POWER OUTPUT	290 W	
NOMINAL AC VOLTAGE	240 VAC	
MAXIMUM AC CURRENT	1.21 A	
CEC EFFICIENCY	97.0%	
ARRAY DETAILS		
NO. OF MODULES PER STRING	7	
NO. OF STRINGS	2	
ARRAY WATTS AT STC	2835	

WIRE/CONDUIT SCHEDULE ARRAY			
TAG	DESCRIPTION	WIRE SIZE/TYPE	NOTES
1	Panel to Micro Inverter	PV Wire (Factory Made)	INTEGRATED
2	Micro Inverter to Micro Inverter	Pre-Manufactured Cable	
3	Micro Inverter to Transition Box	Pre-Manufactured Cable	
3A	Transition Box to Load Center	#10 THHN/THWN-2	
4	Load Center to Utility Disconnect	#10 Cu THHN/THWN-2	
5	Utility Disconnect to aGate	#10 Cu THHN/THWN-2	
6	aPower 2 to Battery Disconnect	#6 Cu THHN/THWN-2	
7	Battery Disconnect to aGate	#6 Cu THHN/THWN-2	
8	aGate to Main Service Panel	4/0 SER AL	
9	aGate to Meter	4/0 SEU AL	
10	Equipment Grounding Conductor	#8 Cu Bare Copper Wire	
11	Equipment Grounding Conductor	#8 Cu THHN/THWN-2	
12	Grounding Electrode Conductor	#6 Cu	

**GENERAL ELECTRIC NOTES: NEC2017**

- EQUIPMENT USED SHALL BE NEW, UNLESS OTHERWISE NOTED.
  - EQUIPMENT USED SHALL BE UL LISTED, UNLESS OTHERWISE NOTED.
  - EQUIPMENT SHALL BE INSTALLED PROVIDING ADEQUATE PHYSICAL WORKING SPACE AROUND THE EQUIPMENT AND SHALL COMPLY WITH NEC.
  - COPPER CONDUCTORS SHALL BE USED AND SHALL HAVE AN INSULATION RATING OF 600V, 90°C, UNLESS OTHERWISE NOTED.
  - CONDUCTORS SHALL BE SIZED IN ACCORDANCE TO THE NEC. CONDUCTORS AMPACITY SHALL BE DE-RATED FOR TEMPERATURE INCREASE, CONDUIT FILL AND VOLTAGE DROP.
  - ALL CONDUCTORS, EXCEPT PV WIRE SHALL BE INSTALLED IN APPROVED CONDUITS OR RACEWAY. CONDUITS SHALL BE ADEQUATELY SUPPORTED AS PER NEC.
  - AC DISCONNECT SHOWN IS REQUIRED IF THE UTILITY REQUIRES VISIBLE-BLADE SWITCH.
  - EXPOSED NON-CURRENT CARRYING METAL PARTS SHALL BE GROUNDED AS PER NEC.
  - LINE SIDE INTER-CONNECTION SHALL COMPLY WITH NEC.
  - SMS MONITORING SYSTEM AND IT'S CONNECTION SHOWN IS OPTIONAL. IF USED, REFER TO SMS INSTALLATION MANUAL FOR WIRING METHODS AND OPERATION PROCEDURE.
  - ASHRAE FUNDAMENTAL OUTDOOR DESIGN TEMPERATURES DO NOT EXCEED 47°C IN THE U.S. (PHOENIX, AZ OR PALM SPRINGS, CA)
  - FOR LESS THAN 9 CURRENT-CARRYING CONDUCTORS IN ROOF MOUNTED SUNLIGHT CONDUIT USING THE OUTDOOR TEMPERATURE OF 47°C
    - 10AWG CONDUCTOR ARE GENERALLY ACCEPTABLE FOR MODULES WITH AN I<sub>sc</sub> OF 9.6 AMPS WITH A 15 AMP FUSE.
- WIRE SIZING FOR OCPD  
EX (I<sub>sc</sub> \* (1.25)(1.25))/# OF STRINGS IN PARALLEL) = WIRE AMPACITY OR USING NEC TABLE 690.8



**SolarEnergyWorld**  
Because Tomorrow Matters

Solar Energy World LLC.  
14880 Sweitzer Lane  
Laurel, MD 20707  
(888) 497-3233

---

**Disclaimer:**  
This drawing is the property of Solar Energy World Inc. The information herein contained shall be used for the sole benefit of Solar Energy World. It shall not be disclosed to others outside the recipient's organization, in whole or in part, without the written permission of Solar Energy World, except in connection with the sale and use of the respective Solar Energy equipment.

---

Building Code: International Residential Code (IRC) 2021  
Electrical Code: National Electrical Code (NEC) 2017

Wind Speed <b>115 MPH</b>	Snow Load <b>30 PSF</b>
------------------------------	----------------------------

---

Modules:  
**(14) LONGi LR5-54HPB-405M**

---

Inverter(s):  
**(14) IQ8+-72-M-US**

---

DC System Size <b>5.670 kW</b>	AC System Size <b>4.060 kW</b>
-----------------------------------	-----------------------------------

---

Customer Information:  
**Jeremiah Frueauf**  
7013 Poplar Ave  
Takoma Park, MD 20912

---

Permit/Lender:  
None

---

City Montgomery	Utility Peppo
--------------------	------------------

---

Sheet Name:  
**Electrical 3-Line Diagram**

---

Drawn By <b>AO</b>	Date <b>December 18, 2025</b>
-----------------------	----------------------------------

---

Scale <b>AS NOTED</b>	Job Number <b>MD29711</b>	Sheet <b>E-2</b>
--------------------------	------------------------------	---------------------



DEPARTMENT OF PERMITTING SERVICES

Marc Elrich  
*County Executive*

Rabbiah Sabbakhan  
*Director*

# HISTORIC AREA WORK PERMIT APPLICATION

Application Date: 1/6/2026

Application No: 1145456  
AP Type: HISTORIC  
Customer No: 1408761

## Affidavit Acknowledgement

The Contractor is the Primary applicant authorized by the property owner  
This application does not violate any covenants and deed restrictions

## Primary Applicant Information

Address 7013 POPLAR AVE  
TAKOMA PARK, MD 20912

Othercontact Solar Energy World (Primary)

## Historic Area Work Permit Details

Work Type ALTER

Scope of Work Install (14) roof mounted solar panels, 5.67 kW